

PRINTED: 01/24/2018
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL086001	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 12/12/2017
NAME OF PROVIDER/SUPPLIER CENTRAL CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 139 APEX LANE MOUNT AIRY, NC 27030			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 000	Initial Comments Report of a Construction Section Biennial Survey by Ed Miller conducted on December 12, 2017. Records indicate that this facility was first licensed on October 6, 1972, for 53 beds. Based on this information, we are requiring the facility to meet the 1967 Edition of the North Carolina State Building Code for Group D-2 Institutional, the 1971 Minimum and Desired Standards and Regulations for Homes for the Aged and Disabled, and the applicable portions of the 2005 Rules for the Licensing of Adult Care Homes of Seven or More Beds. Deficiencies were cited that require a Plan of Correction.	C 000			
C 101	Existing Licensed Fac- No less than 71 Rules SECTION 0300 - PHYSICAL PLANT 10A NCAC 13F .0301 APPLICATION OF PHYSICAL PLANT REQUIREMENTS The physical plant requirements for each adult care home shall be applied as follows: (2) Except where otherwise specified, existing licensed facilities or portions of existing licensed facilities shall meet licensure and code requirements in effect at the time of construction, change in service or bed count, addition, renovation, or alteration; however in no case shall the requirements for any licensed facility where no addition or renovation has been made, be less than those requirements found in the 1971 "Minimum and Desired Standards and Regulations" for "Homes for the Aged and Infirm", copies of which are available at the Division of Health Service Regulation at no cost;	C 101		Brandi Roberts 2-8-18 Administrator	

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

PRINTED: 01/24/2018
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL086001	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 12/12/2017
NAME OF PROVIDER OR SUPPLIER CENTRAL CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 139 APEX LANE MOUNT AIRY, NC 27030			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 101	Continued From page 1 This Rule is not met as evidenced by: Based on observation, the facility does not meet Code at the time of construction or alteration. e. Apic (access in Laundry) - the kitchen hood's exhaust duct is within 18 inches of combustible material. It is wrapped with insulation that does not have a fire-resistance-rating label, therefore it is unknown if this clearance may be reduced because of the wrap.	C 101	(2) e. Kitchen hood was cleaned. Insulation was replaced with fire-resistant-rating insulation.	12/28/2018	
C 111	Must Have Current San. & Fire Safety Reports SECTION 0300 - PHYSICAL PLANT 10A NCAC 13F .0302 DESIGN AND CONSTRUCTION f) The facility shall have current sanitation and fire and building safety inspection reports which shall be maintained in the home and available for review. This Rule is not met as evidenced by: 1. Based on record review, and interview with Maintenance Technician the facility failed to maintain in the facility, current (completed within the last twelve months) annual inspection report(s) required by this Rule. Findings on December 13, 2017: a. A current Fire Marshal Inspection Report was not available for review by the Surveyor.	C 111	(1) a. Administrator contacted local fire marshal to perform annual fire inspection. Fire marshal inspected on 02/06/2018.	02/06/2018	
C 132	Bathrooms - Must Provide Privacy SECTION 0300 - PHYSICAL PLANT 10A NCAC 13F .0305 PHYSICAL ENVIRONMENT (e) The requirements for bathrooms and toilet rooms are:	C 132			

PRINTED: 01/24/2018
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL086001	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 12/12/2017
NAME OF PROVIDER OR SUPPLIER CENTRAL CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 139 APEX LANE MOUNT AIRY, NC 27030			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 132	Continued From page 2 (5) The bathrooms and toilet rooms shall be designed to provide privacy. Bathrooms and toilet rooms with two or more water closets (commodes) shall have privacy partitions or curtains for each water closet. Each tub or shower shall have privacy partitions or curtains. This Rule is not met as evidenced by: 1. Based on observation, the facility failed to ensure that all Bathrooms are designed to provide privacy when there is more than one commode and at the tubs and showers. Findings on December 12, 2017: a. All Group Bathrooms - there are no privacy curtains for the commodes. b. All Group Bathrooms - there are no privacy curtains for the showers and tubs.	C 132	(1) a. Privacy partition walls were built between group bathroom toilets b. Privacy curtain placed in front of shower. A curved commercial rod and curtain was installed for privacy for the bathtubs.	01/04/2018 01/10/2018	
C 164	Housekeeping and Furnishings-Clean, Repaired SECTION 0300 - PHYSICAL PLANT 10A NC/C 13F .0305 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (1) Have walls, ceilings, and floors or floor coverings kept clean and in good repair; (2) Have no chronic unpleasant odors; (3) Have furniture clean and in good repair; (c) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Based on Observation and testing with a thin plastic sheet, the facility failed to maintain the ventilation system in proper working order. This could affect all residents, staff, and visitors by preventing the exhausting of odors. Findings on December 12, 2017: a. Housekeeping near Laundry - the required	C 164	(1) a. Exhaust fan was replaced in the housekeeping closet near the laundry.	01/05/2018	

Division of Health Service Regulation
STATE FORM

0000

TMKV21

If continuation sheet 3 of 11

PRINTED: 01/24/2018
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL006001	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 12/12/2017
NAME OF PROVIDER / SUPPLIER CENTRAL CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 139 APEX LANE MOUNT AIRY, NC 27030			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 185	Continued From page 4	C 185			
C 185	Fire Safety Rehearsals on Each Shift SECTION 10300 - PHYSICAL PLANT 10A NCAC 13F .0309 PLAN FOR EVACUATION (b) There shall be rehearsals of the fire plan quarterly on each shift in accordance with the requirement of the local Fire Prevention Code Enforcement Official. (c) Records of rehearsals shall be maintained and copies furnished to the county department of social services annually. The records shall include the date and time of the rehearsals, the shift staff members present, and a short description of what the rehearsal involved. (f) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Based on Record review and interview with Executive Director/Administrator/Maintenance Director/ Technician/Manager, fire drill rehearsals are not being performed regularly with at least one per shift for each quarter. This deficiency affects all by not having trained staff and trained/cooperative residents when there is a need to evacuate the building. Findings on December 13, 2017: a. In the 1st quarter for the last 12 months, no rehearsal was performed during 2nd and 3rd shift. b. In the 3rd and 4th quarters for the last 12 months, no rehearsal were performed. 2. Based on Record review and interview with Maintenance Technician the Facility failed to document all aspects of the fire plan rehearsals. Findings on December 13, 2017: a. The fire plan rehearsal records included date, time, shift, and staff members present, but little to	C 185	b. Administrator will ensure that fire rehearsals are rehearsed quarterly on each shift. c. Administrator will maintain copies of fire rehearsals including date, time, shift, staff present and description of the rehearsal. a. Fire rehearsal took place for 2nd shift on 02/06/2018 b. Fire rehearsal took place on 3rd shift on 02/06/2018	02/06/2018	

PRINTED: 01/24/2018
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL086001	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 12/12/2017
NAME OF PROVIDER OR SUPPLIER CENTRAL CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 139 APEX LANE MOUNT AIRY, NC 27030		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 189	Continued From page 8 in the room of origin. Findings on December 12, 2017: a. Bedroom B24 - the corridor door has laundry on hangers, hanging on the corridor side of the door, blocking the door from closing and latching. b. Bedroom B24 - the corridor door's strike plate is filled up with paper towels, preventing the door from latching. c. Bedroom B16 - the corridor door has laundry on hangers, hanging on the corridor side of the door, blocking the door from closing and latching. 9. Based on Observation, the corridor doors are not maintained in a safe and operating condition. This affects all by not containing smoke and fire in the room of origin. Findings on December 12, 2017: a. Bedroom 17 - the corridor door had a piece of furniture holding the door open. This prevents the rapid release of the door with a light push or pull of the door, to close and latch. b. Bedroom 18 - the corridor door had two pieces of furniture holding the door open. This prevents the rapid release of the door with a light push or pull of the door, to close and latch.	C 189	(8) a. Laundry hanging on doors were removed from doorknobs. In-serviced staff on hanging laundry on the doors and what a hazard it can be. b. Paper towels were removed from strike plate in Bedroom B24. (9) a. Furniture was removed that was holding bedroom doors open. Will continue to monitor that furniture is not used in this manner.	12/12/2017	12/12/2017
C 191	Unvented & Portable Elec. Heaters Prohibited SECTION 0300 - PHYSICAL PLANT 10/NCAC 13F .0311 OTHER REQUIREMENTS (b) There shall be a heating system sufficient to maintain 75 degrees F (24 degrees C) under winter design conditions. In addition, the following shall apply to heaters and cooking appliances. (2) Unvented fuel burning room heaters and portable electric heaters are prohibited. (k) This Rule shall apply to new and existing	C 191			

PRINTED: 01/24/2018
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL086001	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 12/12/2017
NAME OF PROVIDER OR SUPPLIER CENTRAL CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 139 APEX LANE MOUNT AIRY, NC 27030			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 191	Continued From page 9 facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on Observation, the facility failed to prevent the use portable electric space heaters in an adult Care Home. This could affect residents, staff, and visitors if heater was the ignition source of a fire. The danger increases if used by resident or combustible material were near. Findings on December 12, 2017: a. Side Office - a portable electric space heater found in this room.	C 191	(1) a. Portable heater was removed from side office.	12/12/2017	
C 195	Hot Water System SECTION 0300 - PHYSICAL PLANT 10A NC/C 13F .0311 OTHER REQUIREMENTS (d) The hot water system shall be of such size to provide an adequate supply of hot water to the kitchen, bathrooms, laundry, housekeeping closets and soil utility room. The hot water temperature at all fixtures used by residents shall be maintained at a minimum of 100 degrees F (38 degrees C) and shall not exceed 116 degrees F (46.7 degrees C). (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on Observation, the Facility failed to maintain the hot water temperature at all fixtures used by residents to be a minimum of 100 degrees Fahrenheit and shall not exceed 116 degrees Fahrenheit. Findings on December 12, 2017:	C 195			

Division of Health Service Regulation
STATE FORM

6800

TMKV21

If continuation sheet 10 of 11

PRINTED: 01/24/2018
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL086001	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 12/12/2017
NAME OF PROVIDER/SUPPLIER CENTRAL CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 139 APEX LANE MOUNT AIRY, NC 27030		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 195	Continued From page 10 a. Bathroom across from Bedroom B20 - the sink had a hot water temperature of 85 degrees Fahrenheit.	C 195	(1) a. Mixing valve was replaced. It is a long corridor, so water will take a few minutes to run to meet water temperature requirements.	01/16/2018	

Division of Health Service Regulation
STATE FORM

9800

TMKV21

If continuation sheet 11 of 11

464 Chapter 10 Inspection, Testing, and Maintenance

INSPECTION AND TESTING FORM

DATE: 2-7-13TIME: 9:00 AM

SERVICE ORGANIZATION

Name: INDUSTRIAL FIRE & SAFETY INC.Address: 766 E. SOUTH ST. MT. AIRY, NCRepresentative: JIM PELLLicense No: 8773Telephone: 336-739-5400

PROPERTY NAME (USER)

Name: Central CareAddress: 601

Owner Contact: _____

Telephone: _____

MONITORING ENTITY

Contact: 911

Telephone: _____

Monitoring Account Ref. No: _____

APPROVING AGENCY

Contact: _____

Telephone: _____

TYPE TRANSMISSION

☐ McCulloh☐ Multiplex☐ Digital☐ Reverse☐ RF☒ Other (specify) Dialer

SERVICE

☐ Weekly☐ Monthly☐ Quarterly☐ Semiannually☒ Annually☐ Other (specify) _____Control Unit Manufacturer: ESLCircuit Styles: BNumber of Circuits: 5Software Rev.: CLast Date System Had Any Service Performed: 12-16Last Date that Any Software or Configuration Was Revised: FactoryModel No: 1505

Serial No: _____

ALARM - INITIATING DEVICES AND CIRCUIT INFORMATION

Quantity

Circuit Style

3B010B6B85B00

Manual Fire Alarm Boxes

Ion Detectors

Photo Detectors

Duct Detectors

Heat Detectors

Water flow Switches

Supervisory Switches

Other (Specify) _____

Alarm verification feature is disabled _____ enabled NA

Section 10.6 Records

465

ALARM NOTIFICATION APPLIANCES AND CIRCUIT INFORMATION

Quantity	Circuit Style	
<u>0</u>		BELLS
<u>2</u>	<u>B</u>	HORNS
<u>0</u>		CHIMES
<u>2</u>	<u>B</u>	STROBES
<u>0</u>		SPEAKERS
		Other (Specify) _____

No. of alarm notification appliance circuits: 2Are circuits monitored for integrity? ☒ Yes ☐ No

SUPERVISORY SIGNAL-INITIATING DEVICES AND CIRCUIT INFORMATION

Quantity	Circuit Style	
<u>NA</u>		Building Temp.
		Site Water Temp.
		Site Water Level
		Fire Pump Power
		Fire Pump Running
		Fire Pump Auto Position
		Fire Pump or Pump Controller Trouble
		Generator in Auto Position
		Generator or Controller Trouble
		Switch Transfer
		Generator Engine Running
		Other (Specify) _____

SIGNALING LINE CIRCUITS

QUANTITY and Style (see NFPA 72, Table 3-6) of signaling line circuits connected to system:

Quantity 1 Style B

SYSTEM POWER SUPPLIES

- A. Primary (main): Nominal Voltage 120V Amps 8.5
 Overcurrent Protection: Type Breaker Amps 20
 Location (of Primary Supply Panel board): Hall main
 Disconnecting Means Location: Elec. Room
- B. Secondary (standby):
2 - 12 volt Storage Battery: Amp-Hr. Rating 7 AH
 Calculated capacity to operate system, in hours: ✓ 24 60
NA Engine-driven generator dedicated to fire alarm system
 Location of Fuel Storage: NA

TYPE BATTERY

- ☐ Dry Cell
☐ Nickel-Cadmium
☒ Sealed Lead-Acid
☐ Lead-Acid
☐ Other (specify): _____

- C. Emergency or standby system used as a backup to primary power supply, instead of using a secondary power supply:

NA Emergency system described in NFPA 70, Article 700
NA Legally required standby described in NFPA 70, Article 701
NA Optional standby system described in NFPA 70, Article 702
 which also meets the performance requirements of Article 700 or 701

466 Chapter 10 Inspection, Testing, and Maintenance

PRIOR TO ANY TESTING

NOTIFICATIONS ARE MADE

	YES	NO	WHO	TIME
Monitoring Entity	☒	☐	_____	_____
Building Occupants	☒	☐	_____	_____
Building Management	☒	☐	_____	_____
Other (specify)	☐	☐	_____	_____
AHJ (notified) of any impairments	☐	☐	_____	_____

SYSTEM TESTS AND INSPECTIONS

TYPE

	Visible	Functional	Comments
Control Unit	☒	☒	_____
Interface Equipment	☒	☒	_____
Lamps/LEDS	☒	☒	_____
Fuses	☒	☒	_____
Primary Power Supply	☒	☒	_____
Trouble Signals	☒	☒	_____
Disconnect Switches	☒	☒	_____
Ground Fault Monitoring	☒	☒	_____

SECONDARY POWER

TYPE

	Visible	Functional	Comments
Battery Condition	☒	☒	_____
Load Voltage		☒	_____
Discharge Test		☒	_____
Charger Test		☐	_____
Specific Gravity		☐	_____
Transient Suppressors	☐	☐	_____
Remote Annunciators	☐	☒	_____
Notification Appliances	☒	☒	_____
Audible	☐	☒	_____
Visual	☒	☒	_____
Speakers	☐	☐	_____
Voice Clarity		☐	_____

INITIATING AND SUPERVISORY DEVICE TESTS AND INSPECTIONS

Loc. & S/N	Device Type	Visual Check	Functional Test	Factory Setting	Meas. Setting	Pass	Fail
_____	_____	☐	☐	_____	_____	☐	☐
_____	_____	☐	☐	_____	_____	☐	☐
_____	_____	☐	☐	_____	_____	☐	☐
_____	_____	☐	☐	_____	_____	☐	☐
_____	_____	☐	☐	_____	_____	☐	☐
_____	_____	☐	☐	_____	_____	☐	☐
_____	_____	☐	☐	_____	_____	☐	☐

Comments

Section 10.6 Records

467

EMERGENCY COMMUNICATIONS EQUIPMENT

	Visual	Functional	Comments
Phone Sets	☐	☐	
Phone Jack	☒	☒	
Off-Hook Indicator	☐	☐	
Amplifier	☐	☐	
Tone Generator	☐	☐	
Call-in Signal	☒	☒	
System Performance	☒	☒	

INTERFACE EQUIPMENT

(Specify)	Visual	Device Operation	Simulated Operation
<u>Door Mag.</u>	☒	☒	☒
(Specify)	☐	☐	☐
(Specify)	☐	☐	☐

SPECIAL HAZARD SYSTEMS

(Specify)	Visual	Device Operation	Simulated Operation
<u>NA</u>	☐	☐	☐
(Specify)	☐	☐	☐
(Specify)	☐	☐	☐
Special Procedures			

Comments:

Supervising Station Monitoring	YES	NO	TIME	Comments
Alarm Signal	☐	☐		
Alarm Restoration	☐	☐		
Trouble Signal	☐	☐		
Supervisory Signal	☐	☐		
Supervisory Restoration	☐	☐		

Notifications That Testing Is Complete

	YES	NO	WHO	TIME
Building Management	☒	☐		
Monitoring Agency	☒	☐		
Building Occupants	☒	☐		
Other (specify)	☐	☐		

The Following Did Not Operate Correctly:

System restored to normal operation: Date: 2-7-18 Time: 12:30 PM**THIS TESTING WAS PERFORMED IN ACCORDANCE WITH APPLICABLE NFPA STANDARDS.**Name of Inspector: Jim Pall Date: 2-7-18 Time: 12:30 PMSignature: Jim Pall Brandi Robertson

Name of Owner or Representative: _____

Date: 2-7-18 Time: 12:30 PMSignature: Brandi Robertson