

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL011383	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 02/18/2016
NAME OF PROVIDER OR SUPPLIER SOUNDVIEW II # I		STREET ADDRESS, CITY, STATE, ZIP CODE 36 SMITH GRAVEYARD ROAD ASHEVILLE, NC 28806		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report by Glenn Hoppin DHSR Construction Section conducted a Biennial Survey on February 18, 2016 from 8:00am until 9:30 am at the above referenced facility. DHSR records indicate the home was first licensed on September 23, 1996 as a Family Care Home for six (6) Residents with up to three (3) non-ambulatory residents (un-able to evacuate and respond without any physical or verbal assistance during a fire or other emergency). Based on this information we are requiring the home to maintain compliance with the following: the 1992 Rules for Family Care Homes Minimum and Desired Standards and Regulations, and the applicable portions of the 2005 Rules 10A NCAC 13G for Family Care Homes, the 1996 North Carolina State Building Code - Section 419.3 - Small Residential Care Facilities At the time of our visit, we cited deficiencies that require an acceptable plan of correction. They are as follows:	C 000		
C 174	Building Equipment Maintained Safe, Operating SECTION .0300 - THE BUILDING 10A NCAC 13G .0317 BUILDING SERVICE EQUIPMENT (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in a family care home shall be maintained in a safe and operating condition. (j) This Rule shall apply to new and existing family care homes. This Rule is not met as evidenced by: Observations revealed that the sprinkler inspection tag is not up to date. A work order	C 174	C174 Inspection Tag put on sprinkler. Photo of Tag sent to surveyor. Facility staff will ensure inspection tag is updated annually when inspected by sprinkler company.	3/22/18

Division of Health Service Regulation
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER FCL011383	(X2) MULTIPLE CONSTRUCTION A BUILDING 01 B WING _____	(X3) DATE SURVEY COMPLETED 02/18/2016
---	--	---	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SOUNDVIEW II # I

**36 SMITH GRAVEYARD ROAD
ASHEVILLE, NC 28806**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 174	Continued From page 1 indicated that the sprinkler was inspected on 04/13/2015. Have the sprinkler company update the inspection tag on the sprinkler riser. Provide photo documentation to the DHSR Construction Section when this is completed.	C 174		