

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL078067	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 04/24/2018
NAME OF PROVIDER OR SUPPLIER MORNING STAR AL #4		STREET ADDRESS, CITY, STATE, ZIP CODE 941 GOINS ROAD PEMBROKE, NC 28372		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Construction Section Biennial Survey report by Frank Strickland on 04/24/2018: This facility was licensed on 08/03/1992. Therefore, we are requiring this facility to meet the 1984 Rules for Homes for the Aged, the applicable portions of the 2005 Regulations for Adult Care Homes of Seven or more beds and the 1991 Edition Volume I of the North Carolina State Building Code-Section 409-Institutional Occupancies. The Facility is currently licensed for TWELVE BEDS. Deficiencies have been cited and a Plan of Correction is required.	C 000		
C 166	Housekeeping-Maintained Free of Hazards SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (5) be maintained in an uncluttered, clean and orderly manner, free of all obstructions and hazards; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1-Based on observation, this facility has failed to be free of all obstructions and hazards. Findings on 04/24/2018: The Dining Room entry door was wedged open prevent easy closing in the event of an emergency.	C 166		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL078067	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 04/24/2018
NAME OF PROVIDER OR SUPPLIER MORNING STAR AL #4		STREET ADDRESS, CITY, STATE, ZIP CODE 941 GOINS ROAD PEMBROKE, NC 28372		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 1	C 189		
C 189	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1-Based on observation, this facility has failed to maintain the electrical equipment in a safe and operating condition. Findings on 04/24/2018: The light switch to operate the exhaust fan in the Laundry Room could not be located or has been covered up by a wall switch plate.	C 189		