

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL051008	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/24/2018
NAME OF PROVIDER OR SUPPLIER MCLAMB'S REST HOME #2		STREET ADDRESS, CITY, STATE, ZIP CODE 998 FIVE POINT ROAD BENSON, NC 27504		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Biennial Construction Section Survey reporty by Frank Strickland on 05/24/2018: This facility was first licensed as a Home for the Aged serving 12 residents on 11/03/1983. Therefore this facility was surveyed for conformance with the 1977 and the applicable portions of the 2005 Rules for the Licensing of Adult Care Homes of Seven or More Beds, and, Revision 2 of the 1977 North Carolina State Building Code(s) for Institutional Occupancy. Deficiencies have been cited and a Plan of Correction is required.	C 000		
C 189	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1-Based on observation, this facility has failed to maintain the mechanical equipment in a safe and operating condition. Findings on 04/24/2018: The Kitchen range hood exhaust filter is dirty and has excessive grease build-up. 2-Based on observation, this facility has failed to	C 189		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL051008	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/24/2018
NAME OF PROVIDER OR SUPPLIER MCLAMB'S REST HOME #2		STREET ADDRESS, CITY, STATE, ZIP CODE 998 FIVE POINT ROAD BENSON, NC 27504		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 1 maintain the plumbing equipment in a safe and operating condition. Findings on 04/24/2018: The toilet that is located in Room 6 is not secured to the floor.	C 189		