

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL001151	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 12/14/2018
NAME OF PROVIDER OR SUPPLIER EASTWAY FAMILY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 108 EASTWAY LANE GRAHAM, NC 27253		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report by Paul Dixon DHSR Construction Section conducted a Biennial Survey on December 14, 2018 from 11:45 AM to 1:15 PM at the above referenced facility. DHSR records indicate the home was first licensed on March 23, 2009 as a Family Care Home for six (6) ambulatory Residents (Who are able to respond and evacuate without any physical or verbal assistance during a fire or other emergency). Based on this information we are requiring the home to maintain compliance with the following: the 2005 Rules 10A NCAC 13G for Family Care Homes, the 2006 North Carolina State Building Code - Section 421.2 - Residential Care Homes. NOTES: 1.) At the time of our visit, we cited deficiencies that require an acceptable plan of correction. All deficiencies listed were discussed with on-site staff during the exit interview. 2.) Take actions to correct all listed deficiencies, once completed provide verification in the form of photos, receipts, invoices, etc. for all work performed.	C 000		
C 183	Outside Premises-Clean, Safe SECTION .0300 - THE BUILDING 10A NCAC 13G .0318 OUTSIDE PREMISES (a) The outside grounds of new and existing family care homes shall be maintained in a clean and safe condition. This Rule is not met as evidenced by: 1. At the time of the survey it was observed that	C 183		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL001151	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 12/14/2018
NAME OF PROVIDER OR SUPPLIER EASTWAY FAMILY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 108 EASTWAY LANE GRAHAM, NC 27253		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 183	Continued From page 1 the rear deck and attached ramp had a heavy build-up of snow. This is not compliant with the rule.	C 183		