

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL082022	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 12/06/2018
NAME OF PROVIDER OR SUPPLIER THE MAGNOLIA		STREET ADDRESS, CITY, STATE, ZIP CODE 213 FOREST TRAIL CLINTON, NC 28328		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments Report of a Biennial Follow Up Construction Survey report by Frank Strickland on 12/06/2018: There are previous cited deficiencies from the Biennial Construction Survey that require corrective action and a new Plan of Correction is required.	{C 000}		
{C 133}	Bathrooms-Hand Grips SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0305 PHYSICAL ENVIRONMENT (e) The requirements for bathrooms and toilet rooms are: (6) Hand grips shall be installed at all commodes, tubs and showers used by or accessible to residents; This Rule is not met as evidenced by: 1-Based on observation, all resident bathrooms and toilet room shall have hand grips. Findings on 12/06/2018: There are not any hand grip provided in the bathroom shower off Room 311. This condition is typical throughout the facility.	{C 133}		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE