

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL032020	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/28/2019
NAME OF PROVIDER OR SUPPLIER CROASDAILE VILLAGE		STREET ADDRESS, CITY, STATE, ZIP CODE 2600 CROASDAILE FARM PARKWAY DURHAM, NC 27705		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report of a Biennial Construction Survey by Suzanna Fay conducted on February 28, 2019. Records indicate this facility was first licensed on September 22, 1999. The facility is currently licensed for 30 Beds. Therefore the facility was surveyed for conformance with the 2005 Rules for Licensing of Adult Care Homes of Seven or More Beds and applicable portions of the 1996 (1999 Revision) Edition of the North Carolina Building Code(s), Institutional Occupancy, and the 1996 Rules for Licensing of Adult Care Homes of Seven or More Beds in effect at the time of initial licensure.	C 000		
C 160	Outside Premises-Clean, Safe SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0305 PHYSICAL ENVIRONMENT (m) The requirements for outside premises are: (1) The outside grounds of new and existing facilities shall be maintained in a clean and safe condition; This Rule is not met as evidenced by: 1. Observations revealed that the outside premises were not maintained in a clean and safe condition. Findings on February 28, 2019: a. Insulation boards were placed over the exterior soffits to protect the sprinkler pipes from the cold. The insulation boards are buckling, curling at the edges and separating at the seams.	C 160		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL032020	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/28/2019
NAME OF PROVIDER OR SUPPLIER CROASDAILE VILLAGE		STREET ADDRESS, CITY, STATE, ZIP CODE 2600 CROASDAILE FARM PARKWAY DURHAM, NC 27705		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 164	Continued From page 1	C 164		
C 164	Housekeeping and Furnishings-Clean, Repaired SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (1) have walls, ceilings, and floors or floor coverings kept clean and in good repair; (2) have no chronic unpleasant odors; (3) have furniture clean and in good repair; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Observations revealed that the furnishings were not kept in good repair. Findings on February 28, 2018: a. Kountry Kitchen, D199 Sun Room and the Office - a section of the door veneer has chipped and broken off along the bottom corner at the floor latch. b. Room D108 - the door drags on the frame. c. D182, Men's Toilet - the door drags on the frame. d. Door 32 at the Sunroom drags at the top of the frame. 2. Observations revealed that the walls were not kept in good repair. Findings on February 28, 2019: a. D191, Oxygen/Linen Storage - there are numerous small holes in the wall between the storage room and the mechanical room where shelving was removed. b. Laundry Room - the plastic housing for the washer connections had fallen off of the wall. This was repaired at the time of survey.	C 164		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL032020	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/28/2019
NAME OF PROVIDER OR SUPPLIER CROASDAILE VILLAGE		STREET ADDRESS, CITY, STATE, ZIP CODE 2600 CROASDAILE FARM PARKWAY DURHAM, NC 27705		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on observation there is a failure to maintain the building's fire safety systems in a safe condition. Holes or gaps at penetrations through fire resistant rated ceilings could allow fire and smoke to spread beyond the area of origin. Findings on February 28, 2019: a. Mechanical Room - there is a 1/2" unsealed penetration in the ceiling at the right corner of the room. 2. Based on observation fire safety equipment has not been maintained in a safe and operable condition. All delayed egress doors are to be equipped with signage stating "Push until alarm sounds. Door can be opened in fifteen seconds." Findings on February 28, 2019: a. The door exiting from D wing to the main building is a delayed egress door. The door was not labeled as such which could create panic or confusion. The label was attached at the time of survey.	C 189		