

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL005013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/01/2019
NAME OF PROVIDER OR SUPPLIER ASHE ASSISTED LIVING & MEMORY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 182 CHATTYROB LANE WEST JEFFERSON, NC 28694		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report of a Construction Section Biennial Survey by Ed Miller, conducted on May 1, 2019. Records indicate that this facility was first licensed on 3-25-2011, for 55 beds including 24 beds in a Special Care Unit. Based on this information, the facility was surveyed using the 2005 Rules for the Licensing of Adult Care Homes for Seven or More Beds and the 2009 NC State Building Code(s). Deficiencies were cited that require a Plan of Correction.	C 000		
C 101	Existing Licensed Fac- No less than '71 Rules SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0301 APPLICATION OF PHYSICAL PLANT REQUIREMENTS The physical plant requirements for each adult care home shall be applied as follows: (2) Except where otherwise specified, existing licensed facilities or portions of existing licensed facilities shall meet licensure and code requirements in effect at the time of construction, change in service or bed count, addition, renovation, or alteration; however in no case shall the requirements for any licensed facility where no addition or renovation has been made, be less than those requirements found in the 1971 "Minimum and Desired Standards and Regulations" for "Homes for the Aged and Infirm", copies of which are available at the Division of Health Service Regulation at no cost; This Rule is not met as evidenced by: 1. Based on observation and interview with Executive Director and Maintenance Director, the	C 101		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL005013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/01/2019
NAME OF PROVIDER OR SUPPLIER ASHE ASSISTED LIVING & MEMORY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 182 CHATTYROB LANE WEST JEFFERSON, NC 28694		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 101	Continued From page 1 facility failed to meet the Code requirements in effect at the time of construction or alteration by not having all of the required components for doors equipped with Delayed Egress locking arrangements. This could affect all by potentially delaying exiting in an emergency for more than an acceptable time. Findings on May 1, 2019: a. Exit Door near Nurse Office - the delayed egress locked door, does not have the required sign mounted above and within 12 inches of the releasing device reading: "PUSH UNTIL ALARM SOUNDS. DOOR CAN BE OPENED IN 15 SECONDS". Sign should be of durable construction, with 1-inch high letters, and on a contrasting background. b. Exit Door near Nurse Office - the delayed egress locked door, does not activate the audible signal in the vicinity of the door once the irreversible process to release the door has started.	C 101		
C 111	Must Have Current San. & Fire Safety Reports SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0302 DESIGN AND CONSTRUCTION(f) The facility shall have current sanitation and fire and building safety inspection reports which shall be maintained in the home and available for review. This Rule is not met as evidenced by: 1. Based on record review, and interview with Executive Director and Maintenance Director the facility failed to maintain in the facility, current (completed within the last twelve months) annual inspection report(s) required by this Rule. Findings on May 1, 2019:	C 111		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL005013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/01/2019
NAME OF PROVIDER OR SUPPLIER ASHE ASSISTED LIVING & MEMORY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 182 CHATTYROB LANE WEST JEFFERSON, NC 28694		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 111	Continued From page 2 a. Records indicate that the last Fire Sprinkler System Inspection and Testing report in accordance with NFPA 25 was performed in February 2018, exceeding the requirement to have the system inspected and tested at least annually to insure that the system works properly.	C 111		
C 164	Housekeeping and Furnishings-Clean, Repaired SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (1) have walls, ceilings, and floors or floor coverings kept clean and in good repair; (2) have no chronic unpleasant odors; (3) have furniture clean and in good repair; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Based on observation, the building mechanical systems are not kept clean and in good repair. Findings on May 1, 2019: a. AL Nursing Station - the HVAC return with its radiation damper has an excessive accumulation of dust/lint.	C 164		
C 166	Housekeeping-Maintained Free of Hazards SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (5) be maintained in an uncluttered, clean and orderly manner, free of all obstructions and hazards;	C 166		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL005013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/01/2019
NAME OF PROVIDER OR SUPPLIER ASHE ASSISTED LIVING & MEMORY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 182 CHATTYROB LANE WEST JEFFERSON, NC 28694		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 166	Continued From page 3 (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Based on Observation, the Building was not maintained free of hazards, if oxygen cylinders fall, breaking their valves, propelling the cylinder, and turning it into a dangerous projectile. Findings on May 1, 2019: a. Oxygen Room - four portable medical oxygen cylinders are standing up on the floor in an unapproved plastic crate not physically secured in racks, stands or chained to the structure. 2. Based on Observation, the Building was not maintained free of hazards, because general maintenance was not being done or had not been completed. This could affect all residents, staff, and visitors if items are broken or partially removed and left where they could injure all. Findings on May 1, 2019: a. Bedrooms AL 4 & 6 Shared Bathroom- the mounting bracket for the broken towel bar remain attached to the wall. This bracket is rough and has sharp edges, which provides potential to cause injury. b. AL Hall Bathroom - the mounting brackets for the broken towel bars remain attached to the wall. These brackets are rough and have sharp edges, which provides potential to cause injury. c. Bedrooms AL 19 & 21 Shared Bathroom- the mounting brackets for the broken towel bar remain attached to the wall. These brackets are rough and have sharp edges, which provides potential to cause injury.	C 166		
C 175	Bedroom Furnishings-Clean Towel, Towel Bar	C 175		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL005013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/01/2019
NAME OF PROVIDER OR SUPPLIER ASHE ASSISTED LIVING & MEMORY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 182 CHATTYROB LANE WEST JEFFERSON, NC 28694		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 175	Continued From page 4 SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (b) Each bedroom shall have the following furnishings in good repair and clean for each resident: (7) individual clean towel, wash cloth and towel bar in the bedroom or an adjoining bathroom; and (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Based on observation, the facility failed to provide residents areas, with the required towel bars for each resident. Findings on May 1, 2019: a. Bedrooms AL-4 & 6 and their Shared Bathroom - these single occupancy bedrooms have one of its two towel bars. The second towel bar is broken. b. Bedrooms AL-4 & 6 and their Shared B AL Hall Bathroom - the two towel bars are broken. c. Bedrooms AL-19 & 21 and their Shared Bathroom - these single occupancy bedrooms have one of its two towel bars. The second towel bar is broken.	C 175		
C 185	Fire Safety-Rehearsals on Each Shift SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0309 PLAN FOR EVACUATION (b) There shall be rehearsals of the fire plan quarterly on each shift in accordance with the requirement of the local Fire Prevention Code Enforcement Official. (c) Records of rehearsals shall be maintained and copies furnished to the county department of social services annually. The records shall	C 185		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL005013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/01/2019
NAME OF PROVIDER OR SUPPLIER ASHE ASSISTED LIVING & MEMORY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 182 CHATTYROB LANE WEST JEFFERSON, NC 28694		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 185	Continued From page 5 include the date and time of the rehearsals, the shift, staff members present, and a short description of what the rehearsal involved. (f) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Based on Record review and interview with Executive Director and Maintenance Director, fire safety rehearsals are not being performed regularly with at least one per shift for each quarter. Findings on May 1, 2019: a. In the 1st quarter for the last 12 months, no rehearsals were was performed during 1st and 3rd shifts. b. In the 2nd quarter for the last 12 months, no rehearsals were was performed during 1st and 3rd shifts. c. In the 3rd quarter for the last 12 months, no rehearsals were was performed during 1st and 2nd and 3rd shifts. d. In the 4th quarter for the last 12 months, no rehearsals were was performed during 2nd and 3rd shifts.	C 185		
C 188	Electrical Outlets in Wet Locations SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0310 ELECTRICAL OUTLETS All adult care home electrical outlets in wet locations at sinks, bathrooms and outside of building shall have ground fault interrupters. This Rule is not met as evidenced by: 1. Based on Observation, the facility failed to provide electrical outlets in wet locations outside of building with ground fault interrupters. This	C 188		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL005013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/01/2019
NAME OF PROVIDER OR SUPPLIER ASHE ASSISTED LIVING & MEMORY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 182 CHATTYROB LANE WEST JEFFERSON, NC 28694		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 188	Continued From page 6 would affect residents, staff, and visitors by not providing ground fault protection to these devices. Findings on May 1, 2019: a. AL Courtyard Activity Room Side - the ground-fault circuit-interrupter (GFCI) electrical power receptacle did not have electrical power and could not be tested for ground fault.	C 188		
C 189	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on observation, the Building was not maintained in a safe and operating condition, because the commercial kitchen hood's fire suppression system lacked the inspections, maintenance, and documentation required to ensure a properly working system. This could affect residents, staff, and visitors if the commercial kitchen hood's suppression system fails to operate properly when needed. Findings on May 1, 2019: a. Kitchen -since the last semi-annual maintenance was performed on the commercial kitchen hood's fire suppression system, there has been no documentation of the monthly in-house/owner inspections.	C 189		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL005013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/01/2019
NAME OF PROVIDER OR SUPPLIER ASHE ASSISTED LIVING & MEMORY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 182 CHATTYROB LANE WEST JEFFERSON, NC 28694		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 7 2. Based on observations, the Building fire safety was not maintained in a safe and operating condition. This could expose all to fire/smoke if not contained in room of origin. Findings on May 1, 2019: a. Primary Electrical Room - there are two areas with cable bundles not fully firestopped as they penetrate the fire-resistance-rated ceiling assembly. b. Primary Electrical Room - a cable with its firestopped sealant is pulled out of the fire-resistance-rated ceiling, leaving an unprotected opening. 3. Based on observation, the building's emergency equipment was not maintained in a safe and operating condition. This would affect all if they could not promptly find their way to an exit during an emergency. Findings on May 1, 2019: a. Emergency Electrical Equipment Room - the wall-mounted self-contained emergency light did not illuminate on backup power when the test button is pushed. 4. Based on observation, the smoke tight corridor doors are not maintained in a safe and operating condition. Findings on May 1, 2019: a. Oxygen Room - the corridor door's strike plate is taped over, preventing the door from latching into its frame. Deficiency corrected before Construction Surveyors departed site. 5. Based on observation, the Building Sprinkler System was not maintained in a safe and operating condition. This could affect all if smoke/fire is not contained in the room of origin. Findings on May 1, 2019: a. AL Mech Room near Soiled Utility - the	C 189		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL005013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/01/2019
NAME OF PROVIDER OR SUPPLIER ASHE ASSISTED LIVING & MEMORY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 182 CHATTYROB LANE WEST JEFFERSON, NC 28694		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 8 escutcheon plate on the fire sprinkler has dropped down from the fire-resistance-rated ceiling exposing an opening that allows the spread of smoke and heat. 6. Based on observation, the Facility failed to maintain the electrical system in a safe and operating condition. Findings on May 1, 2019: a. Business Office - an extension cord ran from the Business Office into the corridor under the door to a wax warmer. Extension cords cannot substitute for permanent.	C 189		
C 199	Exhaust Ventilation SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (g) The spaces listed in this Paragraph shall be provided with exhaust ventilation at the rate of two cubic feet per minute per square foot. This requirement does not apply to facilities licensed before April 1, 1984, with natural ventilation in these specified spaces: (1) soiled linen storage; (2) soil utility room; (3) bathrooms and toilet rooms; (4) housekeeping closets; and (5) laundry area. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on Observation and testing with a thin plastic sheet, the facility failed to maintain the ventilation system in proper working order. This could affect all residents, staff, and visitors by	C 199		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL005013	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/01/2019
NAME OF PROVIDER OR SUPPLIER ASHE ASSISTED LIVING & MEMORY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 182 CHATTYROB LANE WEST JEFFERSON, NC 28694		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 199	Continued From page 9 preventing the exhausting of odors. Findings on May 1, 2019: a. SCU Soiled utility - the required exhaust ventilation system did not work.	C 199		