

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL045101	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/02/2019
NAME OF PROVIDER OR SUPPLIER SOUNDVIEW FAMILY CARE HOME UNIT M		STREET ADDRESS, CITY, STATE, ZIP CODE 151 KENDRICK COURT FLAT ROCK, NC 28731		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report by Glenn Hoppin DHSR Construction Section conducted a Biennial Survey on May 2, 2019 from 11:30am until 12:30pm at the above referenced facility. DHSR records indicate the home was first licensed on July 31, 1998 as a Family Care Home for six (6) Residents with up to three (3) non ambulatory residents (unable to respond and evacuate without any physical or verbal assistance during a fire or other emergency). Based on this we are requiring the home to be in compliance with the following: The 1992 Minimum Standards and Regulations for Family Care Homes, the applicable portions of the 2005 Rules for Family Care Homes 10A NCAC 13G, and the 1996 North Carolina State Building Code - Section 419.3 - Small Residential Care facilities. NOTES: 1.) At the time of our visit, we cited deficiencies that require an acceptable plan of correction. All deficiencies listed were discussed with on-site staff during the exit interview. 2.) Take actions to correct all listed deficiencies, once completed provide verification in the form of photos, receipts, invoices, etc. for all work performed. The cited deficiencies are as follows:	C 000		
C 174	Building Equipment Maintained Safe, Operating SECTION .0300 - THE BUILDING 10A NCAC 13G .0317 BUILDING SERVICE EQUIPMENT (a) The building and all fire safety, electrical,	C 174		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL045101	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/02/2019
NAME OF PROVIDER OR SUPPLIER SOUNDVIEW FAMILY CARE HOME UNIT M		STREET ADDRESS, CITY, STATE, ZIP CODE 151 KENDRICK COURT FLAT ROCK, NC 28731		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 174	Continued From page 1 mechanical, and plumbing equipment in a family care home shall be maintained in a safe and operating condition. (j) This Rule shall apply to new and existing family care homes. This Rule is not met as evidenced by: At the time of the survey it was observed that there is a loose electrical receptacle in the last bedroom on the left. This is not compliant with the rule.	C 174		