

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL098023	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 06/26/2019
NAME OF PROVIDER OR SUPPLIER WILSON HOUSE		STREET ADDRESS, CITY, STATE, ZIP CODE 1800 MARTIN LUTHER KING JR. PARKWAY WILSON, NC 27893		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments Report of a Biennial Follow Up Construction Survey by Suzanna Fay conducted on June 26, 2019. There are deficiencies cited in the Biennial Construction Survey that remain to be corrected.	{C 000}		
{C 189}	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1-Based on observation, this facility has failed to maintain the fire safety components in a safe and operating condition by not maintaining corridor walls and doors smoke tight. Findings on June 26, 2019: a. The corridor door for the Kitchen water heater room has been cut for 12" x 12" grille openings at the top and bottom. Note: The gas water heater must have combustion air, but it cannot be from the corridor. A new door has been ordered. 4-Based on observation, this facility has not maintained the interior door in a safe and operating condition. The corridor door for the Kitchen water heater room has been cut for 12" x 12" grille openings at the top and bottom.	{C 189}		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL098023	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 06/26/2019
NAME OF PROVIDER OR SUPPLIER WILSON HOUSE		STREET ADDRESS, CITY, STATE, ZIP CODE 1800 MARTIN LUTHER KING JR. PARKWAY WILSON, NC 27893		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 189}	Continued From page 1 Findings on June 26, 2019: The following interior wood doors are out of adjustment leaving gaps at the top of the door frame that would allow the passage of smoke/fire: (d) Main Hall/Dining Room 5-Based on observation, this facility has not maintained the interior door in a safe and operating condition. Findings on June 26, 2019: The following interior wood doors have damaged door hardware preventing the doors to latch: (d) Storage Closet/300 HALL, Note; The latchset strike is missing on this door. 6-Based on observation, this facility has not maintained the interior door in a safe and operating condition. Finding on June 26, 2019: a. The wood door in the Main Laundry is delaminating and needs replacement. The door has been ordered.	{C 189}		