

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL013046	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 08/16/2019
NAME OF PROVIDER OR SUPPLIER KANNAPOLIS FAMILY CARE HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 2216 KANNAPOLIS HIGHWAY CONCORD, NC 28027		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report by Glenn Hoppin DHSR Construction Section conducted a Biennial Survey on August 16, 2019 from 10:30 AM to 11:30 AM at the above referenced facility. DHSR records indicate the home was first licensed on November 3, 2017 as a Family Care Home for six ambulatory Residents (able to respond and evacuate without any physical or verbal assistance during a fire or other emergency.) Based on this information we are requiring the home to maintain compliance with the following: the 2005 Rules 10A NCAC 13G for Family Care Homes and the applicable portions of the 2012 North Carolina State Building Code - Section 425.2 - Residential Care Homes. NOTES: 1.) At the time of our visit, we cited deficiencies that require an acceptable plan of correction. All deficiencies listed were discussed with on-site staff during the exit interview. 2.) Take actions to correct all listed deficiencies, once completed provide verification in the form of photos, receipts, invoices, etc. for all work performed. The cited deficiencies are as follows:	C 000		
C 174	Building Equipment Maintained Safe, Operating SECTION .0300 - THE BUILDING 10A NCAC 13G .0317 BUILDING SERVICE EQUIPMENT (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in a family care home shall be maintained in a safe and	C 174		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL013046	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 08/16/2019
NAME OF PROVIDER OR SUPPLIER KANNAPOLIS FAMILY CARE HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 2216 KANNAPOLIS HIGHWAY CONCORD, NC 28027		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 174	Continued From page 1 operating condition. (j) This Rule shall apply to new and existing family care homes. This Rule is not met as evidenced by: At the time of the survey it was observed that there is an electrical receptacle in the attic with a missing electrical cover. This is not compliant with the rule.	C 174		