

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL012040	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 08/28/2019
NAME OF PROVIDER OR SUPPLIER JONAS RIDGE ADULT CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 9051 HWY 181 JONAS RIDGE, NC 28641		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments Report of Complaint Follow Up Construction Survey by Dennis Harrell on August 28, 2019. A Construction Section Biennial Survey was conducted at the same time. Deficiencies were cited that will require a plan of correctiuon.	{C 000}		
{C 116}	Plans Submittals and Approvals SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0304 PLANS AND SPECIFICATIONS (a) When construction or remodeling of an adult care home is planned, two copies of Construction Documents and specifications shall be submitted by the applicant or appointed representative to the Division for review and approval. As a preliminary step to avoid last minute difficulty with final plan approval, Schematic Design Drawings and Design Development Drawings may be submitted for approval prior to the required submission of Construction Documents. (b) Approval of Construction Documents and specifications shall be obtained from the Division prior to licensure. Approval of Construction Documents shall expire after one year unless a building permit for the construction has been obtained. (c) If an approval expires, renewed approval shall be issued by the Division, provided revised Construction Documents meeting all current regulations, codes and standards are submitted by the applicant or appointed representative and reviewed by the Division. (d) Any changes made during construction shall require the approval of the Division to assure that licensing requirements are maintained. (e) Completed construction or remodeling shall	{C 116}		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL012040	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 08/28/2019
NAME OF PROVIDER OR SUPPLIER JONAS RIDGE ADULT CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 9051 HWY 181 JONAS RIDGE, NC 28641		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 116}	Continued From page 1 conform to the requirements of this Section including the operation of all building systems and shall be approved in writing by the Division prior to licensure or occupancy. Within 90 days following licensure, the owner or licensee shall submit documentation to the Division that "as built" drawings have been received from the builder. (f) The applicant or designated agent shall notify the Division when actual construction or remodeling starts and at points when construction is 50 percent, 75 percent and 90 percent complete and upon final completion. This Rule is not met as evidenced by: Based on a review of documents, there were no approved Building Inspection documents available for the several new gas pack/air conditioning units recently installed. New air conditioning systems must be inspected and approved. Based on observation, the installation of new HVAC equipment was mostly complete with the following exception; On the day of the survey, a technician was onsite installing a duct mounted smoke detector. Based on interview with the owner/maintenance director the project (project HA-3198) is ready and waiting inspection by the local authorizes.	{C 116}		