PRINTED: 05/29/2024
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING	(X3) DATE SURVEY COMPLETED
	HAL098032		R 05/21/2024

NAME OF PROVIDER OR SUPPLIER: SPRING ARBOR OF WILSON

STREET ADDRESS, CITY, STATE, ZIP CODE: 2045 WARD BOULEVARD, NW, WILSON, NC 27893

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments Report of a Biennial Follow Up Construction Survey by Suzanna Fay conducted on May 21, 2024. There is one deficiency cited in the Biennial Follow Up Construction Survey that remains to be corrected.	{C 000}		
{C 189}	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on observation the facility's fire safety systems are not maintained in a safe condition. Failure to maintain the fire safety systems in a safe condition could affect occupants of the facility if the system did not provide the required fire-resistant rated protection. Findings on May 21, 2024: a. There is one location remaining where the sprinkler head has not been installed, Room 112 in the front of the room.	{C 189}	sprinkler head - custom ordered VSC 5/23/24. Expect install 6/18/24	

Division of Health Service Regulation
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE: Deborah Fox

TITLE: Executive Director

(X6) DATE: 6/04/24