

PRINTED: 04/14/2025
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL064031	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED R 04/02/2025
NAME OF PROVIDER OR SUPPLIER THE GARDENS OF NASHVILLE		STREET ADDRESS, CITY, STATE, ZIP CODE 1022 EASTERN AVENUE NASHVILLE, NC 27856		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
(C 000)	Initial Comments Report of a Biennial Follow Up Construction Survey by Suzanna Fay conducted on April 2, 2025. There is one deficiency cited in the Biennial Construction Survey that remains to be corrected. Therefore, further action is required.	(C 000)	Response to the cited deficiencies does not constitute an admission or agreement by the facility of the truth of the facts alleged or conclusions set forth in the Statement of Deficiencies or Corrective Action Report the Plan of Corrective is prepared solely as a matter of compliance with the State Law.	
(C 189)	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on observation the facility's fire safety equipment is not maintained in operating condition. Failure to maintain fire safety equipment in operating condition could affect occupants of the facility if the equipment did not function as intended during a fire or other emergency. Findings on April 2, 2025: a. The most current annual sprinkler inspection dated February 23, 2024, listed several deficiencies. Staff were not able to provide documentation or a new annual inspection to verify that these items were corrected.	(C 189)	VSC has been contacted by Divisional Maintenance and will schedule a date for inspection. Executive Director and maintenance manager will follow up with corporate office after monthly evaluation and checks pertaining to any upcoming inspections that are needed and schedule them. Facility will create a tickler to alert as updates are needed to be completed before time. This tickler will be checked weekly, and any issues or inspections will be updated as soon as possible to maintain compliance.	5/12/25 and ongoing

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

0099

HXNV25

If continuation sheet 1 of 1

Tracie Gault Executive Director 5-13-25