

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL024015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED R 07/16/2025
--	--	--	---

NAME OF PROVIDER OR SUPPLIER TABOR COMMONS	STREET ADDRESS, CITY, STATE, ZIP CODE 703 ELIZABETH STREET TABOR CITY, NC 28463
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments Report of a Biennial Follow Up Construction Survey by Suzanna Fay conducted on July 16, 2025. There are deficiencies from the Biennial Construction Survey that remain to be corrected.	{C 000}		
{C 116}	Plans Submittals and Approvals SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0304 PLANS AND SPECIFICATIONS (a) When construction or remodeling of an adult care home is planned, two copies of Construction Documents and specifications shall be submitted by the applicant or appointed representative to the Division for review and approval. As a preliminary step to avoid last minute difficulty with final plan approval, Schematic Design Drawings and Design Development Drawings may be submitted for approval prior to the required submission of Construction Documents. (b) Approval of Construction Documents and specifications shall be obtained from the Division prior to licensure. Approval of Construction Documents shall expire after one year unless a building permit for the construction has been obtained. (c) If an approval expires, renewed approval shall be issued by the Division, provided revised Construction Documents meeting all current regulations, codes and standards are submitted by the applicant or appointed representative and reviewed by the Division. (d) Any changes made during construction shall require the approval of the Division to assure that licensing requirements are maintained. (e) Completed construction or remodeling shall conform to the requirements of this Section	{C 116}	Fire alarm panel has been submitted to DHHS on 7/24/25	

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

6899

P1FP22

If continuation sheet 1 of 3

Stephan Williams, ED *Executive Director* *8/16/25*

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL024015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED R 07/16/2025
NAME OF PROVIDER OR SUPPLIER TABOR COMMONS		STREET ADDRESS, CITY, STATE, ZIP CODE 703 ELIZABETH STREET TABOR CITY, NC 28463			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
{C 116}	Continued From page 1 including the operation of all building systems and shall be approved in writing by the Division prior to licensure or occupancy. Within 90 days following licensure, the owner or licensee shall submit documentation to the Division that "as built" drawings have been received from the builder. (f) The applicant or designated agent shall notify the Division when actual construction or remodeling starts and at points when construction is 50 percent, 75 percent and 90 percent complete and upon final completion. This Rule is not met as evidenced by: 1. Based on observation and interview the facility did not submit plans to DHSR/Construction when changes or remodeling was conducted. Findings on July 16, 2025: a. A new fire alarm control panel has been installed since the previous survey. There is no record of plans being submitted to DHSR/Construction for review.	{C 116}			
{C 199}	Exhaust Ventilation SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (g) The spaces listed in this Paragraph shall be provided with exhaust ventilation at the rate of two cubic feet per minute per square foot. This requirement does not apply to facilities licensed before April 1, 1984, with natural ventilation in these specified spaces: (1) soiled linen storage; (2) soil utility room;	{C 199}	Exhaust fans have been ordered and are planned to be installed by 8/31/25		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL024015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 07/16/2025
NAME OF PROVIDER OR SUPPLIER TABOR COMMONS		STREET ADDRESS, CITY, STATE, ZIP CODE 703 ELIZABETH STREET TABOR CITY, NC 28463			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
{C 199}	Continued From page 2 (3) bathrooms and toilet rooms; (4) housekeeping closets; and (5) laundry area. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Observations revealed that the facility did not maintain exhaust ventilation in specified spaces. Lack of ventilation allows for the build up humidity that can cause mildew and slick areas and prevents the dissipation of odors. Findings on July 16, 2025: c. Room 34 Bath - the exhaust fan is not working.	{C 199}	Exhaust fans have been ordered and are planned to be installed by 8/31/25		



- [Close Window](#)
- [Print This Page](#)
- [Expand All](#) | [Collapse All](#)

Tabor Commons-Tabor City - Fire Alarm PM - 2025-07-17

Inspection Name	Tabor Commons-Tabor City - Fire Alarm PM - 2025-07-17		Customer Location	Tabor Commons-Tabor City
Work Order	00017470		Inspection Status	Scheduled
Inspection Date	7/17/2025		Inspection Completed	7/17/2025

Control Panel				
Control Panel MFGR	Notifire	Control Panel MFGR	Other	
Control Panel Model #	10UD-5FP	Control Panel Serial #		
Control Panel Wiring Diag. #		Control Panel Signaling Type		

Batteries				
Voltage w/Charger	☒	Control Panel Battery Type		
Voltage w/o Charger	☒	Control Panel Battery Total #		
Voltage Normal	☒			
Voltage N/A	☐			
Control Panel Batteries Note				

Power Source				
Circuit Breaker Location	Panel A	Circuit Breaker #	3	
Locked Circuit Breaker	No	Dedicated Circuit	Yes	

Trouble Conditions				
Zone Trouble	Norm	Signal Trouble	Norm	
AC/OP Power Loss	Norm	Earth Ground	Norm	
Telco Interface	☒	RJ31 Jack	☒	
Visually Normal	☒	System Normal	☒	
All Connections OK	☒	Upon Arrival	☒	
System Back Online	☒	Customer Request No Signal	☐	
Trouble Conditions Note				

Auxiliary Functions				
Annunciator MFGR	Annunciator MFGR Other			
Annunciator Serial #				
Model Type	Wiring Diagram Voltage			
Wiring Diagram # Zones	Wiring Diagram Unused Pts			

Lamp Test

Remote Reset

Drill SW

Remote Ack

Special Considerations

Doors Holders & Elevator Fire Recall

Door Holders Norm

Door Holders Note

Elevator Fire Recall N/A

Elevator Fire Recall Note

Recall to Alternate Floor

Recall to Alternate Floor Note

Elevators Auto Shutdown

HVAC Shutdown

HVAC Shutdown Norm

HVAC Shutdown Note

Air Handlers

Air Handler Auto Restart

Central Monitoring Station

City Response Norm

City Response Note

Out of Service Time 1:50 PM

In-Service Time 3:50 PM

Local Fire/Central Station

Local Fire/Central Station Phone

Power and Batteries

Power Supply Norm

Power Supply Normal ✓

Power Supply Voltage 27

Power Supply Note

Batteries 01 Normal ✓

Batteries 01 Voltage 14

Batteries 01 Temp

Batteries 01 aHr/

Batteries 01 Note

Batteries 02 Normal ✓

Batteries 02 Voltage 14

Batteries 02 Temp

Batteries 02 aHr/

Batteries 02 Note

Batteries 03 Normal

Batteries 03 Voltage

Batteries 03 Temp

Batteries 03 aHr/

Batteries 03 Note

Batteries 04 Normal

Batteries 04 Voltage

Batteries 04 Temp

Batteries 04 aHr/

Batteries 04 Note

Other Batteries Note

Checklist

Pull Stations ✓

Pull Stations Total # 8

Pull Stations # Checked 8

Annunciators	☐	Annunciators # Checked	
Annunciators Total #			
Duct Detectors	☒	Duct Detectors # Checked	9
Duct Detectors Total #	9		
Horns	☒	Horns # Checked	2
Horns Total #	2		
A/V	☒	A/V # Checked	4
A/V Total #	4		
Bells	☐	Bells # Checked	
Bells Total #			
Strobes	☐	Strobes # Checked	
Strobes Total #			
Chimes	☐	Chimes # Checked	
Chimes Total #			
Sprinkler Systems	☐	Sprinkler Systems # Checked	
Sprinkler Systems Total #			
Voice Evac	☐	Voice Evac # Checked	
Voice Evac Total #			
Heat Detectors	☒	Heat Detectors # Checked	112
Heat Detectors Total #	112		
Smoke Detectors	☒	Smoke Detectors # Checked	28
Smoke Detectors Total #	28		
Beam Detectors	☐	Beam Detectors # Checked	
Beam Detectors Total #			
Areas of Rescue	☐	Areas of Rescue # Checked	
Areas of Rescue Total #			
Other	☐	Other # Checked	
Other Total #			

Summary

NFPA Standards Failures

NFPA Standards
Deviations Note

Tech Signature Lance Ware

Customer Signature

Created By Sara Dellinger, 7/24/2025 11:25 AM

Last Modified By Sara Dellinger, 7/24/2025 11:36 AM

Copyright © 2000-2025 salesforce.com, inc. All rights reserved.