

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL063009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 08/13/2025
NAME OF PROVIDER OR SUPPLIER SAVANNAH FAMILY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 128 NORTH CARLISLE STREET SOUTHERN PINES, NC 28387		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report by AJ Carlock DHSR Construction Section conducted a Biennial Survey on August 13, 2025 from 11:00 AM 12:00 PM at the above referenced facility. DHSR records indicate the home was first licensed on March 2, 1994 as a Family Care Home for six (6) ambulatory Residents (able to respond and evacuate without any physical or verbal assistance during a fire or other emergency.) Based on this information we are requiring the home to maintain compliance with the following: the 1992 Rules 10A NCAC 13G for Family Care Homes, the applicable portions of the 2025 Rules 10A NCAC 13G for Family Care Homes, the 1991 (94 Rev) North Carolina State Building Code - Section 514.1 Exception 1 - Residential Care Homes. NOTES: 1.) At the time of our visit, we cited deficiencies that require an acceptable plan of correction. All deficiencies listed were discussed with on-site staff during the exit interview. 2.) Take actions to correct all listed deficiencies, once completed provide verification in the form of photos, receipts, invoices, etc. for all work performed. The cited deficiencies are as follows:	C 000		
C 031	10A NCAC 13G .0302 (k) Operable windows Design And Construction 10A NCAC 13G .0302 Design And Construction (k) All windows that are designed to be operable	C 031		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation
STATE FORM

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL063009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 08/13/2025
NAME OF PROVIDER OR SUPPLIER SAVANNAH FAMILY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 128 NORTH CARLISLE STREET SOUTHERN PINES, NC 28387		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 102	Continued From page 2	C 102		
C 102	10A NCAC 13G .0317 (a) Maintenance Building Service Equipment 10A NCAC 13G .0317 Building Service Equipment (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in a family care home shall be maintained in a safe and operating condition. This Rule is not met as evidenced by: 1. At the time of the survey it was observed that the storm door in the rear of the building had an eye hook. This is not compliant with the rules. Take the necessary steps to remove the eye hook. 2. At the time of the survey it was observed that the dryer pipe was dirty. This is not compliant with the rules. Take the necessary steps to check the pipe for any holes and clean around the pipe. 3. At the time of the survey it was observed that the staff office had a light switch with no plate. This is not compliant with the rules. Take the necessary steps to add the plate to the light switch. 4. At the time of the survey it was observed that the staff bedroom had carpet that was not properly secured, creating a tripping hazard. This is not compliant with the rules. Take the necessary steps to fix the carpet.	C 102		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL063009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 08/13/2025
NAME OF PROVIDER OR SUPPLIER SAVANNAH FAMILY CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 128 NORTH CARLISLE STREET SOUTHERN PINES, NC 28387		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 102	Continued From page 3 5. At the time of the survey it was observed that the staff bedroom closet had a missing doorknob. This is not compliant with the rules. Take the necessary steps to add the doorknob. 6. At the time of the survey it was observed that both the residents bathrooms handgrips were loose. This is not compliant with the rules. Take the necessary steps to make the handgrips sturdy. 7. At the time of the survey it was observed that the ceiling fan in bedroom 3 was not attached securely. This is not compliant with the rules. Take the necessary steps to fix the ceiling fan. 8. At the time of the survey it was observed that bedroom 3 was so dirty that the room could not be inspected properly. This is not compliant with the rules. Take the necessary steps to clean the rooms so that the window is accessible. 9. At the time of the survey it was observed that the doorknob to bedroom 3 was loose. This is not compliant with the rules. Take the necessary steps to fix the doorknob. 10. At the time of the survey it was observed that the shed door was not attached with hinges and was not locked. This is not compliant with the rules. Take the necessary steps to add a lock and ensure the door is connected to the shed. 11. At the time of the survey it was observed that the second shed had a broken door. This is not compliant with the rules. Take the necessary steps to fix the door.	C 102		