

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL023041	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 09/10/2025
NAME OF PROVIDER OR SUPPLIER GOLDEN YEARS REST HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 630 SUGAR HILL ROAD LAWNDALE, NC 28090		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report of a Construction Section Biennial Survey by Ryan Meyer, conducted on September 10, 2025. A Construction Section Complaint Follow-up Survey was conducted at the same time. Records indicate that this facility was licensed as a Home for the Aged with a capacity of 12 residents on 10/01/1976. Based on this information, this facility was surveyed using the 1967 N.C. State Building Code Section 407-Group "D"- Institutional Occupancy, the 1971 Minimum and Desired Standards and Regulation for Homes for the Aged and Infirm and the applicable portions of the 2005 Rules for the Licensing of Adult Care Homes of Seven or More Beds. Deficiencies were cited that require a Plan of Correction.	C 000		
C 121	10A NCAC 13F .0311(a) Building equipment maintained safe, operating 10A NCAC 13F .0311 Other Requirements (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. This Rule is not met as evidenced by: Based on observation the facility is not maintaining the electrical components located near a water source in a safe manner. Findings on September 10, 2025: a. There are multiple outlets in the laundry room throughout the facility that are not GFCI	C 121		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL023041	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 09/10/2025
NAME OF PROVIDER OR SUPPLIER GOLDEN YEARS REST HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 630 SUGAR HILL ROAD LAWNDALE, NC 28090		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 121	Continued From page 1 protected.	C 121		
C 131	10A NCC 13F .0311(g)(1-5) Other-Exhaust ventilation 10A NCAC 13F .0311 Other Requirements (g) The spaces listed in this Paragraph shall have an exhaust system per the North Carolina State Building Code. Exhaust vents shall be vented directly to the outdoors: (1) soiled linen storage; (2) soiled utility room; (3) bathrooms and toilet rooms; (4) housekeeping closets; and (5) laundry area. This Rule is not met as evidenced by: 1. The facility is not keeping its exhaust fans in operable condition. Findings on September 10, 2025: a. The exhaust fan in the bathing room is not working.	C 131		