

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: fcl079113	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 08/28/2025
NAME OF PROVIDER OR SUPPLIER HARRISONS CARING HANDS		STREET ADDRESS, CITY, STATE, ZIP CODE 814 LINDSEY STREET REIDSVILLE, NC 27320		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments Report by David Hickman DHSR Construction Section conducted a Biennial Follow-up Survey on August 28, 2025 from 9:05 AM to 9:25 AM at the above referenced facility. Not all of the previously cited deficiencies were verified as being corrected. Therefore, further action is required. The remaining cited deficiencies are as follows:	{C 000}		
{C 174}	Building Equipment Maintained Safe, Operating SECTION .0300 - THE BUILDING 10A NCAC 13G .0317 BUILDING SERVICE EQUIPMENT (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in a family care home shall be maintained in a safe and operating condition. (j) This Rule shall apply to new and existing family care homes. This Rule is not met as evidenced by: 1.) At the time of the survey, it was observed that the call system had a Tone Off button that mutes the system. This is not compliant with the rule. Take the necessary steps to disable the Tone Off button. * At the time of the survey, the call system was not working and could not be tested. Repair the call system. 2.) At the time of the survey, it was observed that bedroom #3 window does not stay open. This could potentially impede egress in a time of need. This is not compliant with the rule. Take the necessary steps to repair and or replace the window.	{C 174}		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: fcl079113	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 08/28/2025
NAME OF PROVIDER OR SUPPLIER HARRISONS CARING HANDS			STREET ADDRESS, CITY, STATE, ZIP CODE 814 LINDSEY STREET REIDSVILLE, NC 27320		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
{C 174}	Continued From page 1 * This deficiency had not been corrected.	{C 174}			