


DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/06/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355091	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING	(X3) DATE SURVEY COMPLETED 09/30/2014
---	---	--	---



NAME OF PROVIDER OR SUPPLIER ASHLEY MEDICAL CENTER NURSING HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 612 CENTER AVE N ASHLEY, ND 58413
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------------	--	---------------------	--	----------------------------

K 000 INITIAL COMMENTS

This survey used the 2000 edition of NFPA 101, Life Safety Code, Chapter 19-Existing Health Care Occupancies in compliance with 42CFR 483.70(a). The findings that follow demonstrate noncompliance with these standards.

The facility was located in a two-story combined Hospital and Long Term Care building of Type II (000) construction that was separated from residential living apartments with a 2 hour fire resistance rated occupancy separation. The building was protected by a wet automatic sprinkler system designed to meet the requirements of the 1999 edition of NFPA 13, Standard for the Installation of Sprinkler Systems.

K 062
SS=F

NFPA 101 LIFE SAFETY CODE STANDARD

Required automatic sprinkler systems are continuously maintained in reliable operating condition and are inspected and tested periodically. 19.7.6, 4.6.12, NFPA 13, NFPA 25, 9.7.5

This STANDARD is not met as evidenced by:
The facility failed to ensure the automatic sprinkler system was continuously maintained in a reliable operating condition as required by NFPA 25, Standard for the Inspection, Testing and Maintenance of Water-based Fire Protection Systems.

On 09/30/2014, record review determined the facility failed to conduct a quarterly test of the sprinkler system during the 4th quarter of 2013 and the 1st quarter of 2014.

K 000

K 062

K 062:

It is the policy of the Ashley Medical Center that the facility must ensure that the automatic sprinkler system is continuously maintained in a reliable operation condition and inspected and tested quarterly.

A hose will be placed over sprinkler head and ran into drain for testing in the winter months to prevent ice built up preventing patient access.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

[Signature] *[Signature]* 10/14/2014

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

*emailed
10-22-14*

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/08/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355091	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/30/2014
NAME OF PROVIDER OR SUPPLIER ASHLEY MEDICAL CENTER NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 612 CENTER AVE N ASHLEY, ND 58413		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 062	Continued From page 1	K 062	The sprinkler system will be inspected, tested, and maintained in accordance with NFPA 25, decreasing the risk of death or injury due to fire.	11/14/14	
K 144 SS=F	Failure to test and maintain the automatic sprinkler system in accordance with NFPA 25 increases the risk of death or injury due to fire. The deficiency affected two (2) of four (4) quarterly tests of the automatic sprinkler system, which serves the entire facility. NFPA 101 LIFE SAFETY CODE STANDARD Generators are inspected weekly and exercised under load for 30 minutes per month in accordance with NFPA 99. 3.4.4.1. This STANDARD is not met as evidenced by: The facility failed to ensure the emergency generator was in compliance with NFPA 110, Standard for Emergency and Standby Power Systems. All Level 1 and Level 2 installations of an emergency generator shall have a remote manual stop station of a type similar to a break-glass station located outside the room housing the prime mover, where so installed, or located elsewhere on the premises where the prime mover is located outside the building. For Level 1 and Level 2 systems located outdoors, the manual shutdown should be located	A QA will be done quarterly for one year. Responsible Parties: Environmental K 144: It is the policy of the Ashley Medical Center that the facility must ensure the emergency generator is in compliance with NFPA 99 and 110. This will be done with the installation of a remote manual stop station with a break-glass shut off switch located outside the room housing the generator. Salzer Electric had been notified of the need of this shut off switch prior to our inspection (please see exhibit #1), he has since been notified of the need to reorder the switch to include a break-glass feature. He has insured us that once the switch comes in he will be installing it. A QA will be done quarterly until switch is installed. Responsible Parties: Environmental Service Director, and Administrator.	11/14/14		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/08/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355091	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/30/2014
NAME OF PROVIDER OR SUPPLIER ASHLEY MEDICAL CENTER NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 612 CENTER AVE N ASHLEY, ND 58413		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 144	Continued From page 2 external to the weatherproof enclosure and should be appropriately identified. NFPA 110. Observation determined there was no remote stop switch for the generator located outside of the generator room. Failure to inspect and maintain the emergency generators in accordance with NFPA 99 and NFPA 110 increases the risk of death or injury due to fire. The deficiency affected one (1) of one (1) emergency generator which provides all emergency power to the facility.	K 144			