

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/20/2010
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - KNIFE RIVER CARE CENT B. WING DIVISION OF LIFE SAFETY AND CONSTRUCTION	(X3) DATE SURVEY COMPLETED 04/19/2010
---	--	---	--

NAME OF PROVIDER OR SUPPLIER

KNIFE RIVER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**118 22ND ST NE
BEULAH, ND 58523**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS This survey used the 2000 edition of NFPA 101, Life Safety Code, Chapter 18 New Health Care Occupancies in compliance with 42 CFR 483.70(a) and NDAC 33-07-04.2-09 (1)(c). The facility is located in a one-story building of Type V (111) construction built in 2007. The building is equipped with an automatic wet and dry sprinkler system with quick response sprinklers designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems.	K 000		
K 029 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD Hazardous areas are protected in accordance with 8.4. The areas are enclosed with a one hour fire-rated barrier, with a 3/4 hour fire-rated door, without windows (in accordance with 8.4). Doors are self-closing or automatic closing in accordance with 7.2.1.8. 18.3.2.1 This STANDARD is not met as evidenced by: The facility failed to separate hazardous areas from other spaces with one-hour fire resistive rated partitions and fire-rated door assemblies. Observation determined the 90-minute fire-rated Purchasing Storage Room door was damaged beyond repair. This door can no longer maintain the required fire rating of the opening.	K 029	A new one hour fire resistive door with self-closing device will be installed to replace damaged door into purchasing storage room. KRCC Maintenance department, in conjunction with quarterly proper latching door checks will also check for damaged doors. See exhibit # 1. K 029 Continuous Quality Improvement focus will be added to current CQI meeting agenda with quarterly reviews.	June 3, 2010

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

[Signature]
ADMINISTRATOR

04-26-10

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.