

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/16/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355053		(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - KNIFE RIVER CARE CENT B. WING _____		(X3) DATE SURVEY COMPLETED R 07/12/2011	
NAME OF PROVIDER OR SUPPLIER KNIFE RIVER CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 118 22ND ST NE BEULAH, ND 58523			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		
{K 000}	INITIAL COMMENTS			{K 000}			
	This survey used the 2000 edition of NFPA 101, Life Safety Code, Chapter 18 New Health Care Occupancies in compliance with 42 CFR 483.70(a). The findings demonstrate noncompliance with these standards. The facility is located in a one-story building of Type V (111) construction built in 2007. The building is equipped with an automatic wet and dry sprinkler system with quick response sprinklers designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems.						
{K 130}	NFPA 101 MISCELLANEOUS			{K 130}			
SS=F	OTHER LSC DEFICIENCY NOT ON 2786 This STANDARD is not met as evidenced by: A functional test must be conducted on every required emergency lighting system at 30-day intervals for not less than 30 seconds. An annual test must be conducted on every required battery-powered emergency lighting system for not less than 1 1/2-hours. Equipment must be fully operational for the duration of the test. Written records of visual inspection and tests must be kept by the owner for inspection. 7.9.3 The facility failed to assure maintenance and testing of emergency lighting. Observation determined the battery-powered lighting in the garage and above the emergency generator transfer switch failed the 1 1/2-hour annual test.				6/7/11		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.