

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355053		(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - KNIFE RIVER CARE CENTER B. WING _____		(X3) DATE SURVEY COMPLETED 04/05/2017	
NAME OF PROVIDER OR SUPPLIER KNIFE RIVER CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 118 22ND ST NE BEULAH, ND 58523			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS This survey used the 2012 edition of NFPA 101, Life Safety Code, Chapter 19-Existing Health Care Occupancies and the 2012 edition of NFPA 99, Health Care Facilities Code in compliance with 42 CFR 483.70(a)(b). The findings that follow demonstrate noncompliance with these standards. The facility was located in a one-story building of Type V (111) construction with a partial basement. The building was equipped with an automatic wet and dry sprinkler system with quick response sprinklers designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems.			K 000			
K 211 SS=E	NFPA 101 Means of Egress - General Means of Egress - General Aisles, passageways, corridors, exit discharges, exit locations, and accesses are in accordance with Chapter 7, and the means of egress is continuously maintained free of all obstructions to full use in case of emergency, unless modified by 18/19.2.2 through 18/19.2.11. 18.2.1, 19.2.1, 7.1.10.1 This STANDARD is not met as evidenced by: During its swing, any door in a means of egress shall leave not less than one-half of the required width of an aisle, corridor, passageway, or landing unobstructed and shall not project more than 7 inches into the required width of an aisle, corridor, passageway, or landing, when fully open. 7.2.1.4.3.1 The facility failed to ensure exit access was readily accessible at all times.			K 211	1. Handrails near the identified areas were removed on April 6, 2017 to ensure compliance of seven inches clearance and also the means of egress is free of all obstructions to full instant use in case of emergency. 2. Maintenance will complete an inspection of entire facility so all identified egress areas are free from obstruction.		5/20/17

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

04/14/2017

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - KNIFE RIVER CARE CENTER B. WING _____		(X3) DATE SURVEY COMPLETED 04/05/2017
NAME OF PROVIDER OR SUPPLIER KNIFE RIVER CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 118 22ND ST NE BEULAH, ND 58523		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 211	Continued From page 1 Observation determined the following corridor doors opened outward into the exit corridor and extended more than 7 inches from the wall when fully opened. 1) The corridor door to the Housekeeping Closet in the Elm Grove Household. 2) The corridor door to the Housekeeping Closet in the Harvest Lane Household. 3) The corridor door to the Housekeeping Closet in the Golden Grain Household. 4) The corridor door to the Housekeeping Closet in the Cottonwood Grove Household. Failure to maintain the means of egress to be available at all times increases the risk of death or injury due to fire. The deficiency affected four (4) of numerous corridor doors in the means of egress throughout the facility.	K 211	3. A monthly inspection will be completed by Maintenance personnel. 4. Quarterly QAPI will be completed by Maintenance on all egress areas. (See Exhibit A) Education will be provided at the April 19, 2017 General Staff meeting. 5. Completion date of May 20, 2017.		
K 347 SS=F	NFPA 101 Smoke Detection Smoke Detection 2012 EXISTING Smoke detection systems are provided in spaces open to corridors as required by 19.3.6.1. 19.3.4.5.2 This STANDARD is not met as evidenced by: Smoke detectors must not be located in a direct airflow nor closer than 3 ft. (1 m) from an air supply diffuser or return air opening. 19.3.4.5.1, 9.6.2.10.1.1, NFPA 72 17.7.4.1. The facility failed to ensure the smoke detection system was in compliance with NFPA 72, National Fire Alarm and Signaling Code.	K 347	1. Facility will relocate smoke detectors that are located to close to direct airflow or air supply will be relocated. The facility's fire system contractor has been scheduled to move those smoke detectors to ensure with compliance. 2. Maintenance will do an inspection of the smoke detectors in the building.		5/20/17

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - KNIFE RIVER CARE CENTER B. WING _____		(X3) DATE SURVEY COMPLETED 04/05/2017
NAME OF PROVIDER OR SUPPLIER KNIFE RIVER CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 118 22ND ST NE BEULAH, ND 58523		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 347	Continued From page 2 Observation determined smoke detectors throughout the facility were installed within 3 ft. of an air supply diffuser or air supply vent. Failure to install the smoke detection system as required increases the risk of death or injury due to fire. This deficiency affected numerous smoke detectors in the facility. The smoke detection system serves the entire facility.	K 347	3. Facility's fire system contractor tests smoke detector system on regular basis. Documentation of those tests will be kept on file. Maintenance will also conduct an annual smoke detector inspection. 4. Results of smoke detector tests and inspections will be reviewed after each test and inspection. If the results show a smoke detector location to be out of compliance, the facility will relocate the identified detector to ensure compliance. Education will be provided at the April 19, 2017 General Staff meeting. 5. Completion date of May 20, 2017.	5/20/17	
K 351 SS=D	NFPA 101 Sprinkler System - Installation Spinkler System - Installation 2012 EXISTING Nursing homes, and hospitals where required by construction type, are protected throughout by an approved automatic sprinkler system in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems. In Type I and II construction, alternative protection measures are permitted to be substituted for sprinkler protection in specific areas where state or local regulations prohibit sprinklers. In hospitals, sprinklers are not required in clothes closets of patient sleeping rooms where the area of the closet does not exceed 6 square feet and sprinkler coverage covers the closet footprint as required by NFPA 13, Standard for Installation of Sprinkler Systems. 19.3.5.1, 19.3.5.2, 19.3.5.3, 19.3.5.4, 19.3.5.5,	K 351			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - KNIFE RIVER CARE CENTER B. WING _____		(X3) DATE SURVEY COMPLETED 04/05/2017
NAME OF PROVIDER OR SUPPLIER KNIFE RIVER CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 118 22ND ST NE BEULAH, ND 58523		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 351	Continued From page 3 19.4.2, 19.3.5.10, 9.7, 9.7.1.1(1) This STANDARD is not met as evidenced by: Buildings containing nursing homes shall be protected throughout by an approved, supervised automatic sprinkler system. Sprinklers in walk-in type coolers and freezers with automatic defrosting shall be of the intermediate-temperature classification or higher. 19.3.5.1, 9.7.1.1(1), NFPA 13 8.3.2, 8.3.2.5(10) The facility failed to install the automatic sprinkler system in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems to provide adequate coverage for all portions of the building. Observation determined one (1) sprinkler in the walk-in freezer located in the Kitchen was of ordinary-temperature classification. The walk-in freezer was equipped with an automatic defrosting feature. Failure to install and maintain the automatic sprinkler system in accordance with NFPA 13 increases the risk of injury and death due to fire. The deficiency affected one (1) of numerous sprinklers in the facility. The automatic sprinkler system serves the entire facility.	K 351	1. Facility contacted facility's sprinkler system contractor in February 2017 to change the sprinkler heads in the walk in coolers and freezer. Contractor will be changing the sprinkler heads in May 2017 when they are on site for the quarterly sprinkler inspection. 2. No other areas of facility has walk in coolers or freezers. Therefore, no other areas of facility are affected. 3. Maintenance will complete a quarterly inspection of the walk in cooler and freezer sprinkler system. (See Exhibit B) 4. Results of quarterly inspections will be reviewed at quarterly QAPI meetings. Education will be provided at the April 19, 2017 General Staff meeting. 5. Completion date of May 20, 2017.		
K 901 SS=F	NFPA 101 Fundamentals - Building System Categories Fundamentals - Building System Categories Building systems are designed to meet Category 1 through 4 requirements as detailed in NFPA 99. Categories are determined by a formal and documented risk assessment procedure performed by qualified personnel.	K 901		5/20/17	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - KNIFE RIVER CARE CENTER B. WING _____		(X3) DATE SURVEY COMPLETED 04/05/2017
NAME OF PROVIDER OR SUPPLIER KNIFE RIVER CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 118 22ND ST NE BEULAH, ND 58523		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 901	Continued From page 4 Chapter 4 (NFPA 99) This STANDARD is not met as evidenced by: The facility failed to provide a documented risk assessment of building systems. NFPA 99, 4.2 Review of documentation and interview of staff determined the facility failed to conduct and document a risk assessment of building systems. Failure to conduct a risk assessment of building systems increases the risk of injury or death due to fire. This deficiency affected building systems throughout the entire facility.	K 901	1. Facility will define and document a defined risk assessment procedure for categorizing facility systems. (See Exhibit C and D) 2. All building systems and all areas of the building will be included in the assessment. Assessments will be documented and maintained. 3. Maintenance Department Personnel will be provided education on April 13, 2017. (See exhibit E) Education that will be provided will be on the Facility Risks Assessment Procedure and how to properly complete a Facility Risk Assessment Form. Education will be provided at the April 19, 2017 General Staff meeting. 4. Reassessments will be completed when changes to a system have been made or change occur in procedures or type of equipment used in area. 5. Completion date of May 20, 2017		
K 923 SS=D	NFPA 101 Gas Equipment - Cylinder and Container Storag Gas Equipment - Cylinder and Container Storage Greater than or equal to 3,000 cubic feet Storage locations are designed, constructed, and	K 923		5/20/17	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - KNIFE RIVER CARE CENTER B. WING _____		(X3) DATE SURVEY COMPLETED 04/05/2017
NAME OF PROVIDER OR SUPPLIER KNIFE RIVER CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 118 22ND ST NE BEULAH, ND 58523		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 923	Continued From page 5 ventilated in accordance with 5.1.3.3.2 and 5.1.3.3.3. >300 but <3,000 cubic feet Storage locations are outdoors in an enclosure or within an enclosed interior space of non- or limited- combustible construction, with door (or gates outdoors) that can be secured. Oxidizing gases are not stored with flammables, and are separated from combustibles by 20 feet (5 feet if sprinklered) or enclosed in a cabinet of noncombustible construction having a minimum 1/2 hr. fire protection rating. Less than or equal to 300 cubic feet In a single smoke compartment, individual cylinders available for immediate use in patient care areas with an aggregate volume of less than or equal to 300 cubic feet are not required to be stored in an enclosure. Cylinders must be handled with precautions as specified in 11.6.2. A precautionary sign readable from 5 feet is on each door or gate of a cylinder storage room, where the sign includes the wording as a minimum "CAUTION: OXIDIZING GAS(ES) STORED WITHIN NO SMOKING." Storage is planned so cylinders are used in order of which they are received from the supplier. Empty cylinders are segregated from full cylinders. When facility employs cylinders with integral pressure gauge, a threshold pressure considered empty is established. Empty cylinders are marked to avoid confusion. Cylinders stored in the open are protected from weather. 11.3.1, 11.3.2, 11.3.3, 11.3.4, 11.6.5 (NFPA 99) This STANDARD is not met as evidenced by: Medical gas storage and administration areas shall be protected in accordance with NFPA 99, Standards for Health Care Facilities. 19.3.2.4	K 923	1. Light switch was changed to a drop over protective cover on 04/11/2017. The light switch cover is locked.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - KNIFE RIVER CARE CENTER B. WING _____		(X3) DATE SURVEY COMPLETED 04/05/2017
NAME OF PROVIDER OR SUPPLIER KNIFE RIVER CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 118 22ND ST NE BEULAH, ND 58523		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 923	Continued From page 6 Electrical devices should be physically protected, such as by use of a protective barrier around the electrical devices, or by location of the electrical device such that it will avoid causing physical damage to the cylinders or containers. For example, the device could be located at or above 1.5m (5 ft) above finished floor or other location that will not allow the possibility of the cylinders or containers to come into contact with the electrical device as required by this section. NFPA 99, A.5.1.3.3.2(5) The facility failed to ensure nonflammable medical gas equipment and systems were in compliance with NFPA 99. In oxygen storage rooms containing more than 300 cu. ft. of gas, all electrical wall fixtures must be physically protected or located at least five (5) feet above the floor. Observation determined the Oxygen Storage Room contained over 300 cu. ft. of oxygen and had electrical wall fixtures that were unprotected and installed less than five (5) feet above the floor. This deficiency affected one (1) of one (1) oxygen storage room in the facility.	K 923	2. No other areas of facility are affected. 3. Education will be provided at the April 19, 2017 General Staff meeting. 4. Maintenance will inspect light switch on a quarterly basis. 5. Completion date April 20, 2017.		