

North Dakota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 8202	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 - BENEDICTINE LIVING COMMUNITIES B. WING _____	(X3) DATE SURVEY COMPLETED 05/21/2019
NAME OF PROVIDER OR SUPPLIER BENEDICTINE LIVING COMMUNITIES-BISMAR		STREET ADDRESS, CITY, STATE, ZIP CODE 4580 COLEMAN STREET BISMARCK, ND 58503		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
K 000	INITIAL COMMENTS This survey used the 2012 edition of NFPA 101, Life Safety Code, Chapter 32 New Residential Board and Care Occupancies (Large), in compliance with NDAC 33-03-24.2. The facility was located on the first floor and lower level of a three-story structure of Type II (111) construction protected throughout with a wet automatic fire sprinkler system designed to meet the requirements of NFPA 13, Standard for the Installation of Sprinkler Systems. The basic care facility was separated from an assisted living facility on the second and third floors and a parking garage on the lower level by 2-hour fire resistant rated occupancy separation barriers. Resident evaluation determined a Slow level of evacuation difficulty. The E-Score was 2.55. Note: At the conclusion of the 05/20/2019 Life Safety Code survey, it was determined the facility was in compliance with the provisions of NFPA 101, Life Safety Code.	K 000		

Health Resources Section

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE