

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/30/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355093		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/21/2019	
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - BOTTINEAU				STREET ADDRESS, CITY, STATE, ZIP CODE 725 E 10TH ST BOTTINEAU, ND 58318			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS This survey used the 2012 edition of NFPA 101, Life Safety Code, Chapter 19-Existing Health Care Occupancies and the 2012 edition of NFPA 99, Health Care Facilities Code in compliance with 42 CFR 483.70(a)(b). The findings that follow demonstrate noncompliance with these standards. The facility was located in a one-story building of Type V (000) construction with a wet automatic fire sprinkler system designed to meet the requirements of NFPA 13, Standard for the Installation of Sprinkler Systems.			K 000			
K 321 SS=D	Hazardous Areas - Enclosure CFR(s): NFPA 101 Hazardous Areas - Enclosure Hazardous areas are protected by a fire barrier having 1-hour fire resistance rating (with 3/4 hour fire rated doors) or an automatic fire extinguishing system in accordance with 8.7.1 or 19.3.5.9. When the approved automatic fire extinguishing system option is used, the areas shall be separated from other spaces by smoke resisting partitions and doors in accordance with 8.4. Doors shall be self-closing or automatic-closing and permitted to have nonrated or field-applied protective plates that do not exceed 48 inches from the bottom of the door. Describe the floor and zone locations of hazardous areas that are deficient in REMARKS. 19.3.2.1, 19.3.5.9 Area Automatic Sprinkler Separation N/A a. Boiler and Fuel-Fired Heater Rooms b. Laundries (larger than 100 square feet)			K 321			5/31/19

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

06/04/2019

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/30/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355093	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/21/2019
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - BOTTINEAU			STREET ADDRESS, CITY, STATE, ZIP CODE 725 E 10TH ST BOTTINEAU, ND 58318		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 321	Continued From page 1 c. Repair, Maintenance, and Paint Shops d. Soiled Linen Rooms (exceeding 64 gallons) e. Trash Collection Rooms (exceeding 64 gallons) f. Combustible Storage Rooms/Spaces (over 50 square feet) g. Laboratories (if classified as Severe Hazard - see K322) This REQUIREMENT is not met as evidenced by: Any hazardous areas shall be safeguarded by a fire barrier having a 1-hour fire resistance rating or shall be provided with an automatic extinguishing system. Where the sprinkler option is used, the areas shall be separated from other spaces by smoke-resisting partitions and doors. The doors shall be self-closing or automatic-closing. 19.3.2.1 The facility failed to ensure hazardous areas were separated from other areas with self-closing doors. Observation determined the corridor door to the Janitor Room near the Business Office lacked a self-closing device. The Janitor Room was larger than 50 square feet and was used to store combustible materials. Failure to ensure hazardous areas were separated from other spaces by self-closing, latching doors increases the risk of death or injury due to fire. The deficiency affected one (1) of numerous hazardous areas in the facility.	K 321	1. A self-closer will be installed on the Janitor Room door. 2. The entire facility has the potential to be affected; the Environmental Service Director or a designee will complete a walk through and identify any hazardous areas and ensure that a self-closer is installed on doors located in a hazardous area. 3. The environmental service director and Environmental service Assistant will receive education on the facilities policy titled "Protections in Hazardous Areas". This policy reviews the requirements for hazardous areas, to ensure our staff is educated to prevent the deficient practice from occurring again. 4. An audit will be completed monthly for 6 months on all hazardous areas to ensure there is a self-closer installed on doors located in a hazardous area. The audit results will be brought to the QAPI committee for review. 5. A self-closer was installed on the Janitor Room door on 5/31/19.		
K 345 SS=F	Fire Alarm System - Testing and Maintenance CFR(s): NFPA 101	K 345			7/3/19

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/30/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355093		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/21/2019	
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - BOTTINEAU				STREET ADDRESS, CITY, STATE, ZIP CODE 725 E 10TH ST BOTTINEAU, ND 58318			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 345	Continued From page 2 Fire Alarm System - Testing and Maintenance A fire alarm system is tested and maintained in accordance with an approved program complying with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code. Records of system acceptance, maintenance and testing are readily available. 9.6.1.3, 9.6.1.5, NFPA 70, NFPA 72 This REQUIREMENT is not met as evidenced by: Health care occupancies shall be provided with a fire alarm system in accordance with Section 9.6. 19.3.4.1 A fire alarm system required for life safety shall be installed, tested, and maintained in accordance with the applicable requirements of NFPA 70, National Electrical Code and NFPA 72, National Fire Alarm and Signaling Code. 9.6.1.3. 2010 NFPA 72, 14.1.1 The facility failed to test the fire alarm system as required. Fire alarm system batteries shall be subjected to a load voltage test semiannually. NFPA 72, 14.4.2.2 item 5(e) Review of fire alarm system test records indicated the semiannual load voltage tests of the sealed lead acid batteries were not performed as required. A load voltage test of the fire alarm system batteries was done during the annual inspection by an outside company on 03/07/2019, and on 06/22/2018. The time between tests exceeds 6 months.			K 345	1. Load voltage tests of the fire alarm batteries will be completed every six months and documented. 2. The entire facility has the potential to be affected because the fire alarm system serves the entire facility. 3. The environmental service director and Environmental service Assistant will receive education on the facilities policy titled "Detection, Alarm and Communication systems". This policy reviews the requirements for semi-annual tests of the load voltage fire alarm battery test to ensure our staff is educated to prevent the deficient practice from occurring again. 4. An audit will be completed every 3 months for a year to ensure load voltage tests of the fire alarm batteries are being completed and documented every 6 months. 5. The load voltage test of the fire alarm batteries will be completed every six months. The last documented test was completed on 3/6/19; the next test will be completed and documented by 9/6/19.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/30/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355093	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/21/2019
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - BOTTINEAU			STREET ADDRESS, CITY, STATE, ZIP CODE 725 E 10TH ST BOTTINEAU, ND 58318		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 345	Continued From page 3	K 345			
K 351 SS=E	Failure to install, test and maintain the fire alarm system in accordance with NFPA 72 increases the risk of death or injury due to fire. This deficiency affected one (1) of two (2) required load voltage tests of the fire alarm batteries in the past year. The fire alarm system serves the entire facility. Sprinkler System - Installation CFR(s): NFPA 101 Sprinkler System - Installation 2012 EXISTING Nursing homes, and hospitals where required by construction type, are protected throughout by an approved automatic sprinkler system in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems. In Type I and II construction, alternative protection measures are permitted to be substituted for sprinkler protection in specific areas where state or local regulations prohibit sprinklers. In hospitals, sprinklers are not required in clothes closets of patient sleeping rooms where the area of the closet does not exceed 6 square feet and sprinkler coverage covers the closet footprint as required by NFPA 13, Standard for Installation of Sprinkler Systems. 19.3.5.1, 19.3.5.2, 19.3.5.3, 19.3.5.4, 19.3.5.5, 19.4.2, 19.3.5.10, 9.7, 9.7.1.1(1) This REQUIREMENT is not met as evidenced by: Buildings containing nursing homes shall be protected throughout by an approved, supervised automatic sprinkler system. 19.3.5.1, 9.7.1.1(1)	K 351	1. All sprinkler heads within a 7 ft. radius cylinder extending 7 ft. above and 2 ft. below horizontal discharge unit heaters will be replaced with a high temperature		7/3/19

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/30/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355093	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/21/2019
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - BOTTINEAU			STREET ADDRESS, CITY, STATE, ZIP CODE 725 E 10TH ST BOTTINEAU, ND 58318		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 351	Continued From page 4 The facility failed to install the automatic sprinkler system in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems to provide adequate coverage for all portions of the building. Sprinklers in high-temperature zones shall be high-temperature classification, and sprinklers in intermediate-temperature zones shall be intermediate-temperature classification. NFPA 13 8.3.2, 8.3.2.5(1), Table 8.3.2.5(a)(2) NFPA 13 requires high-temperature-rated sprinklers within a 7 ft. radius cylinder extending 7 ft. above and 2 ft. below horizontal discharge unit heaters. Observation determined one (1) sprinkler in Rooms 315, 318, and 409 was installed within 7 ft. of wall-mounted horizontal discharge unit heaters and was not high-temperature-rated. Failure to install the automatic sprinkler system in accordance with NFPA 13 increases the risk of injury and death due to fire. This deficiency affected three (3) of numerous areas in the facility. The automatic sprinkler system serves the entire facility.	K 351	rated sprinkler head. 2. The entire facility has the potential to be affected; the Environmental Service Director or a designee will complete a walk through and identify any sprinkler heads that are within a 7 ft. radius cylinder extending 7 ft. above and 2 ft. below horizontal discharge unit heaters. 3. The environmental service director and Environmental service Assistant will receive education on the facilities policy titled "Extinguisher and Fire Suppression System Requirements". This policy reviews the requirement for sprinkler systems in the facility to ensure our staff is educated to prevent the deficient practice from occurring again. 4. An audit will be completed monthly for 6 months on all sprinkler heads within a 7 ft. radius cylinder extending 7 ft. above and 2 ft. below horizontal discharge unit heaters ensuring they have the proper temperature rated sprinkler head. The audit results will be brought to the QAPI committee for review. 5. All affected sprinkler heads will be changed to a high temperature rated sprinkler head by 7/3/2019.		
K 355 SS=D	Portable Fire Extinguishers CFR(s): NFPA 101 Portable Fire Extinguishers Portable fire extinguishers are selected, installed, inspected, and maintained in accordance with NFPA 10, Standard for Portable Fire Extinguishers. 18.3.5.12, 19.3.5.12, NFPA 10	K 355		7/3/19	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/30/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355093	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/21/2019
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - BOTTINEAU			STREET ADDRESS, CITY, STATE, ZIP CODE 725 E 10TH ST BOTTINEAU, ND 58318		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 355	Continued From page 5 This REQUIREMENT is not met as evidenced by: Portable fire extinguishers shall be provided in all health care occupancies. Extinguishers shall be selected, installed, inspected, and maintained in accordance with NFPA 10, Standard for Portable Fire Extinguishers. 19.3.5.12, 9.7.4.1 Fire extinguishers having a gross weight not exceeding 40 lb. (18.14 kg) shall be installed so that the top of the fire extinguisher is not more than 5 ft (1.53 m) above the floor. Fire extinguishers having a gross weight greater than 40 lb. (18.14 kg) (except wheeled types) shall be installed so that the top of the fire extinguisher is not more than 3 1/2 ft (1.07 m) above the floor. In no case shall the clearance between the bottom of the hand portable fire extinguisher and the floor be less than 4 in. (102 mm). NFPA 10 6.1.3.8.1, 6.1.3.8.2, 6.1.3.8.3 The facility failed to install fire extinguishers in accordance with NFPA 10. Observation determined a portable fire extinguisher in the corridor near Room 212 was installed with the top of the extinguisher more than 5 ft. above the floor. Failure to install fire extinguishers in accordance with NFPA 10 increases the risk of injury or death due to fire. The deficiency affected one (1) of numerous fire extinguishers in the facility.	K 355	1. All portable fire extinguishers that are installed with the top of the extinguisher more than 5 ft. above the floor will be moved in accordance with NFPA 10. 2. The entire facility has the potential to be affected; the Environmental Service Director or a designee will complete a walk through and identify any portable fire extinguishers that are installed with the top of the extinguisher more than 5 ft. above the floor. 3. The environmental service director and Environmental service Assistant will receive education on the facilities policy titled "Extinguisher and Fire Suppression System Requirements". This policy reviews the requirements for portable extinguishers to ensure our staff is educated to prevent the deficient practice from occurring again. 4. An audit will be completed monthly for 6 months on all portable fire extinguishers ensuring they are installed in accordance with NFPA 10. 5. All affected portable fire extinguishers will be moved and reinstalled in accordance with NFPA 10 by 7/3/2019.		