

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355111		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017	
NAME OF PROVIDER OR SUPPLIER ST LUKES SUNRISE CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 705 SE 4TH ST CROSBY, ND 58730			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS			K 000			
K 211 SS=D	This survey used the 2012 edition of NFPA 101, Life Safety Code, Chapter 19-Existing Health Care Occupancies and the 2012 edition of NFPA 99, Health Care Facilities Code in compliance with 42 CFR 483.70(a)(b). The findings that follow demonstrate noncompliance with these standards. The facility was located in a one-story building of Type V (000) construction that was protected with a dry automatic sprinkler system designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems and smoke detection throughout the corridor system. NFPA 101 Means of Egress - General Means of Egress - General Aisles, passageways, corridors, exit discharges, exit locations, and accesses are in accordance with Chapter 7, and the means of egress is continuously maintained free of all obstructions to full use in case of emergency, unless modified by 18/19.2.2 through 18/19.2.11. 18.2.1, 19.2.1, 7.1.10.1 This STANDARD is not met as evidenced by: Means of egress must be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency. The width of means of egress shall be measured in the clear at the narrowest point of the exit component under consideration. Exception: Projections not more than 4 1/2 in. (8.9 cm) on each side shall be permitted at 38 in. (96 cm) and below. 7.1.10.1, 7.3.2.2 The facility failed to ensure exit access was			K 211	1. The water fountain will be relocated. 2. All current water fountains are within code. The entire facility is at risk of this deficient practice. 3. Area will be kept clear at all times. 4. The area will be audited to ensure it is kept clear at all times. Audits will be completed 3 random days throughout the month to ensure proper clearance is		6/19/17

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

06/01/2017

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355111	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER ST LUKES SUNRISE CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 705 SE 4TH ST CROSBY, ND 58730		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 211	Continued From page 1 readily accessible at all times. Observation determined a water fountain that was located in the corridor by the north exit door between the 300 Wing and the 400 Wing extended approximately sixteen (16) inches from the corridor wall and protruded into the exit corridor. Failure to maintain the means of egress to be available at all times increases the risk of death or injury due to fire. The deficiency affected egress from one (1) of six (6) exits in the facility.	K 211	maintained. Audits will be completed x 12 months.		
K 347 SS=F	NFPA 101 Smoke Detection Smoke Detection 2012 EXISTING Smoke detection systems are provided in spaces open to corridors as required by 19.3.6.1. 19.3.4.5.2 This STANDARD is not met as evidenced by: Smoke detectors must not be located in a direct airflow nor closer than 3 ft. (1 m) from an air supply diffuser or return air opening. 19.3.4.5.1, 9.6.2.10.1.1, NFPA 72 17.7.4.1. The facility failed to ensure the smoke detection system was in compliance with NFPA 72, National Fire Alarm and Signaling Code. Observation determined smoke detectors throughout the facility were installed within 3 ft. of an air supply diffuser or air return vent. Failure to install the smoke detection system as required increases the risk of death or injury due	K 347	1. All smoke detectors will be moved to have more than 3 feet clearance from any direct airflow or air supply diffuser or return air opening. 2. All smoke detectors are checked to ensure appropriate clearance. 3. Any new smoke detectors added will be in compliance. 4. An audit will be completed at the end of the completion period to ensure all smoke detectors. A quarterly audit will be added to TELS to ensure all smoke	6/30/17	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355111	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER ST LUKES SUNRISE CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 705 SE 4TH ST CROSBY, ND 58730		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 347	Continued From page 2 to fire.	K 347	detectors remain in compliance of clearance.	6/30/17	
K 351 SS=D	This deficiency affected numerous smoke detectors in the facility. The smoke detection system serves the entire facility. NFPA 101 Sprinkler System - Installation Spinkler System - Installation 2012 EXISTING Nursing homes, and hospitals where required by construction type, are protected throughout by an approved automatic sprinkler system in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems. In Type I and II construction, alternative protection measures are permitted to be substituted for sprinkler protection in specific areas where state or local regulations prohibit sprinklers. In hospitals, sprinklers are not required in clothes closets of patient sleeping rooms where the area of the closet does not exceed 6 square feet and sprinkler coverage covers the closet footprint as required by NFPA 13, Standard for Installation of Sprinkler Systems. 19.3.5.1, 19.3.5.2, 19.3.5.3, 19.3.5.4, 19.3.5.5, 19.4.2, 19.3.5.10, 9.7, 9.7.1.1(1) This STANDARD is not met as evidenced by: Buildings containing nursing homes shall be protected throughout by an approved, supervised automatic sprinkler system. Sprinklers in walk-in type coolers and freezers with automatic defrosting shall be of the intermediate-temperature classification or higher. 19.3.5.1, 9.7.1.1(1), NFPA 13 8.3.2, 8.3.2.5(10) The facility failed to install the automatic sprinkler system in accordance with NFPA 13, Standard	K 351	1. The sprinkler heads in the walk-in freezer will be replaced to meet the code. 2. The entire facility is at risk of this deficient practice. All automatic sprinkler heads with the exception of the sprinkler heads in the walk-in freezer currently meet life safety code. 3. If a sprinkler head fails the facility will		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355111	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER ST LUKES SUNRISE CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 705 SE 4TH ST CROSBY, ND 58730		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 351	Continued From page 3 for the Installation of Sprinkler Systems to provide adequate coverage for all portions of the building. Observation determined one (1) sprinkler in the walk-in freezer located in the Kitchen was of ordinary-temperature classification. The walk-in freezer was equipped with an automatic defrosting feature. Failure to install and maintain the automatic sprinkler system in accordance with NFPA 13 increases the risk of injury and death due to fire. The deficiency affected one (1) of numerous sprinklers in the facility. The automatic sprinkler system serves the entire facility.	K 351	replace with device that continues to meet code. 4. An audit will be completed quarterly through the TELS system to ensure all sprinkler heads continue to meet life safety code.	6/1/17	
K 353 SS=F	NFPA 101 Sprinkler System - Maintenance and Testing Sprinkler System - Maintenance and Testing Automatic sprinkler and standpipe systems are inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintaining of Water-based Fire Protection Systems. Records of system design, maintenance, inspection and testing are maintained in a secure location and readily available. a) Date sprinkler system last checked _____ b) Who provided system test _____ c) Water system supply source _____ Provide in REMARKS information on coverage for any non-required or partial automatic sprinkler system.	K 353			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355111	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER ST LUKES SUNRISE CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 705 SE 4TH ST CROSBY, ND 58730		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 353	Continued From page 4 9.7.5, 9.7.7, 9.7.8, and NFPA 25 This STANDARD is not met as evidenced by: Automatic sprinkler systems are continuously maintained in reliable operating condition and are inspected and tested periodically. The property owner or designated representative shall correct or repair deficiencies or impairments that are found during the inspection, test, and maintenance required by NFPA 25, Standard for the Inspection, Testing and Maintenance of Water-based Fire Protection Systems. 19.7.6, 4.6.12, NFPA 25, 5.1.1.2 The facility failed to ensure the automatic sprinkler system was continuously maintained in a reliable operating condition as required by NFPA 25. Review of documentation and interview of staff determined none of the required inspections and tests of the automatic sprinkler system were conducted during the third quarter of 2017. Inspections and tests include: 1) Inspect gauges of dry system weekly. 2) Inspect control valves quarterly. 3) Inspect water alarm devices quarterly. 4) Inspect valve supervisory alarm devices quarterly. 5) Inspect supervisory signal devices quarterly. 6) Inspect hydraulic nameplate quarterly. 7) Test waterflow alarm devices quarterly. This deficiency affected numerous inspections and tests of the automatic sprinkler system. The automatic sprinkler system serves the entire facility.	K 353	1. Facility will be proactive in contacting outside vendors to complete mandated testing. 2. The entire facility is at risk of this deficient practice. 3. All outside vendors will be contacted to make sure testing dates are scheduled in the mandated timeframe. 4. An audit will be added to TELS to be completed quarterly to ensure testing is completed in the mandated timeframe.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355111	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER ST LUKES SUNRISE CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 705 SE 4TH ST CROSBY, ND 58730		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 353	Continued From page 5	K 353			
K 753	Failure to inspect and test the automatic sprinkler system in accordance with NFPA 25 increases the risk of injury or death due to fire.				
SS=D	NFPA 101 Combustible Decorations Combustible Decorations Combustible decorations shall be prohibited unless one of the following is met: * Flame retardant or treated with approved fire-retardant coating that is listed and labeled for product. * Decorations meet NFPA 701. * Decorations exhibit heat release less than 100 kilowatts in accordance with NFPA 289. * Decorations, such as photographs, paintings and other art are attached to the walls, ceilings and non-fire-rated doors in accordance with 18.7.5.6 or 19.7.5.6. * The decorations in existing occupancies are in such limited quantities that a hazard of fire is not present. 18.7.5.6, 19.7.5.6 This STANDARD is not met as evidenced by: Combustible decorations shall be prohibited in any health care occupancy, unless one of the following criteria is met: (1) They are flame-retardant or are treated with approved fire-retardant coating that is listed and labeled for application to the material to which it is applied. (2) The decorations meet the requirements of NFPA 701, Standard Methods of Fire Tests for Flame Propagation of Textiles and Films. (3) The decorations exhibit a heat release rate not exceeding 100 kW when tested in	K 753	1. The resident met with facility administration, environmental services manager, social worker and region ombudsman on 5/30/2017 to discuss the need to remove articles on the wall to meet life safety code. All other resident rooms will be checked to ensure compliance. 2. The entire facility is at risk of this deficient practice. 3. New policy is being created (pending board approval) to explain the requirements for decorations of the		6/30/17

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355111	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER ST LUKES SUNRISE CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 705 SE 4TH ST CROSBY, ND 58730		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 753	Continued From page 6 accordance with NFPA 289, Standard Method of Fire Test for Individual Fuel Packages, using the 20 kW ignition source. (4)*The decorations, such as photographs, paintings, and other art, are attached directly to the walls, ceiling, and non-fire-rated doors in accordance with the following: (a) Decorations on non-fire-rated doors do not interfere with the operation or any required latching of the door and do not exceed the area limitations of 19.7.5.6(b), (c), or (d). (b) Decorations do not exceed 20 percent of the wall, ceiling, and door areas inside any room or space of a smoke compartment that is not protected throughout by an approved automatic sprinkler system in accordance with Section 9.7. (c) Decorations do not exceed 30 percent of the wall, ceiling, and door areas inside any room or space of a smoke compartment that is protected throughout by an approved supervised automatic sprinkler system in accordance with Section 9.7. (d) Decorations do not exceed 50 percent of the wall, ceiling, and door areas inside patient sleeping rooms, having a capacity not exceeding four persons, in a smoke compartment that is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7. (5)*They are decorations, such as photographs and paintings, in such limited quantities that a hazard of fire development or spread is not present. 19.7.5.6	K 753	residents room. 4. An audit will be completed on 5 random resident rooms each month x 12 months to ensure decorations in place meet life safety code.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355111	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER ST LUKES SUNRISE CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 705 SE 4TH ST CROSBY, ND 58730		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 753	Continued From page 7 The facility failed to ensure decorations complied with NFPA 101. Observation determined Resident Room 403 had combustible decorations covering approximately 80% of the walls and corridor door. Failure to ensure combustible materials attached to walls and corridor doors comply with NFPA 101 increases the risk of injury or death due to fire. This deficiency affected one (1) of numerous rooms in the facility,	K 753			
K 920 SS=D	NFPA 101 Electrical Equipment - Power Cords and Extens Electrical Equipment - Power Cords and Extension Cords Power strips in a patient care vicinity are only used for components of movable patient-care-related electrical equipment (PCREE) assemblies that have been assembled by qualified personnel and meet the conditions of 10.2.3.6. Power strips in the patient care vicinity may not be used for non-PCREE (e.g., personal electronics), except in long-term care resident rooms that do not use PCREE. Power strips for PCREE meet UL 1363A or UL 60601-1. Power strips for non-PCREE in the patient care rooms (outside of vicinity) meet UL 1363. In non-patient care rooms, power strips meet other UL standards. All power strips are used with general precautions. Extension cords are not used as a substitute for fixed wiring of a structure. Extension cords used temporarily are removed immediately upon completion of the purpose for	K 920			6/30/17

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355111	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER ST LUKES SUNRISE CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 705 SE 4TH ST CROSBY, ND 58730		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 920	Continued From page 8 which it was installed and meets the conditions of 10.2.4. 10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5 This STANDARD is not met as evidenced by: All power strips shall be used with general precautions. Extension cords are not used as a substitute for fixed wiring of a structure. Flexible cords and cables shall not be used for the following: (1) As a substitute for the fixed wiring of a structure. (2) Where run through holes in walls, structural ceilings, suspended ceilings, dropped ceilings, or floors. (3) Where run through doorways, windows, or similar openings. (4) Where attached to building surfaces. NFPA 70, National Electrical Code, 2010 Edition Section 400-8. The facility failed to ensure power strips were used with general precautions. Observation determined a power strip and two (2) 3-way plugs were "daisy-chained" together for personal equipment in Resident Room 403. Failure to ensure the electrical wiring complies with NFPA 70 for all portions of the building increases the risk of injury and death due to fire. The deficiency affected one (1) of three (3)	K 920	1. All 3-way plugs will be removed. All resident rooms will be checked for extension cords and 3-way plugs and removed if found. 2. The entire facility is at risk of this deficient practice. 3. New policy is being created (pending board approval) to explain the requirements for electrical outlets and cords in the resident's rooms. 4. An audit will be completed on 5 random resident rooms each month x 12 months to ensure compliance with life safety code.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/10/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355111	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER ST LUKES SUNRISE CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 705 SE 4TH ST CROSBY, ND 58730		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 920	Continued From page 9 smoke compartments in the facility.	K 920			