

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/27/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355069		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 11/23/2021	
NAME OF PROVIDER OR SUPPLIER EVENTIDE HEARTLAND				STREET ADDRESS, CITY, STATE, ZIP CODE 620 14TH AVE NE DEVILS LAKE, ND 58301			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 000	Initial Comments			E 000			
K 000	A certification survey conducted on November 23, 2021 found Eventide Heartland in compliance with the requirements of 483.73 Long Term Care Emergency Preparedness. INITIAL COMMENTS This survey used the 2012 edition of NFPA 101, Life Safety Code, Chapter 19-Existing Health Care Occupancies and the 2012 edition of NFPA 99, Health Care Facilities Code in compliance with 42 CFR 483.70(a)(b). The facility was located in a one-story building of Type V (000) construction and a one-story building of Type II (000) construction. The building was protected with an automatic sprinkler system designed to meet the requirements of NFPA 13, Standard for the Installation of Sprinkler Systems. A one-story garage addition of Type II (000) was attached to the original building in 1993. This addition had no automatic sprinkler system and does not meet the requirements for a health care occupancy. According to staff, nursing facility residents do not receive treatment or services in this building. This building was separated from the nursing facility by an occupancy separation wall of two-hour fire resistance rating. This building was not reviewed as a component of this Life Safety Code survey. Observation and records review determined the facility to be in compliance with the minimum requirements of the 2012 Life Safety Code and NFPA 99.			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

11/29/2021

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.