

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/18/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355067		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/08/2015	
NAME OF PROVIDER OR SUPPLIER VALLEY ELDERCARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 2900 14TH AVE S GRAND FORKS, ND 58201			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS This survey used the 2000 edition of NFPA 101, Life Safety Code, Chapter 18 New Health Care Occupancies and Chapter 19 Existing Health Care Occupancies, in compliance with 42 CFR 483.70(a). The facility is a one-story building of Type V (000) existing construction and a one-story building of Type V (111) new construction. The one-story building of existing construction and the one-story building of new construction are separated by a wall having a two-hour fire resistance rating. The one-story building of new construction was surveyed under Chapter 18 New Health Care Occupancies. The building was protected throughout by an automatic fire sprinkler system designed to meet the requirements of the 1999 edition of NFPA 13, Standard for the Installation of Sprinkler Systems. A clinic was attached to the north side of the facility and was separated by an occupancy separation wall having a two-hour fire resistance rating. Note: At the conclusion of the 09/08/2015 Life Safety Code survey, it was determined the facility was in compliance with the provisions of NFPA 101, Life Safety Code.			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

09/09/2015

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.