

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/15/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355051		(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 09/09/2024	
NAME OF PROVIDER OR SUPPLIER HATTON PRAIRIE VILLAGE				STREET ADDRESS, CITY, STATE, ZIP CODE 950 DAKOTA AVE HATTON, ND 58240			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 000	Initial Comments A recertification survey conducted on 09/09/2024 found Hatton Prairie Village in compliance with the requirements of 483.73 Long-Term Care Facilities Emergency Preparedness.			E 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
Electronically Signed		09/24/2024

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/15/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355051		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/09/2024	
NAME OF PROVIDER OR SUPPLIER HATTON PRAIRIE VILLAGE				STREET ADDRESS, CITY, STATE, ZIP CODE 950 DAKOTA AVE HATTON, ND 58240			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS This survey used the 2012 edition of NFPA 101, Life Safety Code, Chapter 19-Existing Health Care Occupancies and the 2012 edition of NFPA 99, Health Care Facilities Code in compliance with 42 CFR 483.70(a)(b). The findings that follow demonstrate noncompliance with these standards. The facility was located in a one-story building of Type II (000) construction protected throughout by a wet automatic sprinkler system designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems. A two-hour fire rated occupancy separation wall was constructed between the nursing home and the attached assisted living facility to the north.			K 000			
K 914 SS=D	Electrical Systems - Maintenance and Testing CFR(s): NFPA 101 Electrical Systems - Maintenance and Testing Hospital-grade receptacles at patient bed locations and where deep sedation or general anesthesia is administered, are tested after initial installation, replacement or servicing. Additional testing is performed at intervals defined by documented performance data. Receptacles not listed as hospital-grade at these locations are tested at intervals not exceeding 12 months. Line isolation monitors (LIM), if installed, are tested at intervals of less than or equal to 1 month by actuating the LIM test switch per 6.3.2.6.3.6, which activates both visual and audible alarm. For LIM circuits with automated self-testing, this manual test is performed at intervals less than or equal to 12 months. LIM circuits are tested per 6.3.3.3.2 after any repair or renovation to the			K 914			10/24/24

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

09/24/2024

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/15/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355051	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/09/2024
NAME OF PROVIDER OR SUPPLIER HATTON PRAIRIE VILLAGE			STREET ADDRESS, CITY, STATE, ZIP CODE 950 DAKOTA AVE HATTON, ND 58240		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 914	Continued From page 1 electric distribution system. Records are maintained of required tests and associated repairs or modifications, containing date, room or area tested, and results. 6.3.4 (NFPA 99) This REQUIREMENT is not met as evidenced by: Electrical systems shall be inspected, tested and maintained in accordance with the applicable requirements of NFPA 99 Health Care Facilities Code. 6.3.3.2, 6.3.3.2.1, 6.3.3.2.2, 6.3.3.2.3, 6.3.3.2.4, 6.3.4.1 Receptacle inspection and testing in patient care rooms shall include the following: 1) The physical integrity of each receptacle shall be confirmed by visual inspection. 2) The continuity of the grounding circuit in each electrical receptacle shall be verified. 3) Correct polarity of the hot and neutral connections in each electrical receptacle shall be confirmed. 4) The retention force of the grounding blade of each electrical receptacle (except locking-type receptacles) shall be not less than 115 g (4 oz). Failed receptacles at patient bed locations shall be replaced with hospital grade outlets, per NFPA 70 National Electrical Code, 517.18 (B). These tests need to be completed at least annually on all non-hospital grade outlets in patient care rooms. The facility failed to ensure the electrical system was inspected, tested and maintained in accordance with NFPA 99 Health Care Facilities Code.	K 914	1. All electrical outlets in all resident rooms will be inspected and tested to ensure correct polarity in each outlet, that no outlets are broken and that there is correct receptacle tension in each outlet, in accordance with NFPA 99 Health Care Facilities Code. 2. No other areas or portions of the facility have the potential to be affected by the deficient practice. 3. The inspection and testing of all electrical outlets in all resident rooms will be done annually and will be added to the facility's annual maintenance checklist. Any broken outlets will be replaced immediately with hospital-grade outlets. 4. QAPI Committee will review the annual maintenance checklist to ensure the inspection and testing of all electrical outlets in all resident rooms was completed timely.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/15/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355051	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/09/2024
NAME OF PROVIDER OR SUPPLIER HATTON PRAIRIE VILLAGE			STREET ADDRESS, CITY, STATE, ZIP CODE 950 DAKOTA AVE HATTON, ND 58240		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 914	Continued From page 2 Observation, record review, and interview with staff determined there was no documentation of inspection and testing of the non-hospital grade electrical receptacles at patient bed locations in the past year. Failure to inspect, test and maintain electrical receptacles in accordance with NFPA 99 increases the risk of death or injury due to fire. The deficiency affected numerous electrical receptacles in all resident rooms in the facility.	K 914			