

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/02/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355051		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/30/2020	
NAME OF PROVIDER OR SUPPLIER HATTON PRAIRIE VILLAGE				STREET ADDRESS, CITY, STATE, ZIP CODE 950 DAKOTA AVE HATTON, ND 58240			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 000	Initial Comments			E 000			
K 000	A recertification survey conducted on September 30, 2020 found Hatton Prairie Village in compliance with the requirements of 483.73 Long Term Care Emergency Preparedness. INITIAL COMMENTS			K 000			
K 324 SS=D	This survey used the 2012 edition of NFPA 101, Life Safety Code, Chapter 19-Existing Health Care Occupancies and the 2012 edition of NFPA 99, Health Care Facilities Code in compliance with 42 CFR 483.70(a)(b). The findings that follow demonstrate noncompliance with these standards. The facility was located in a one-story building of Type II (000) construction protected throughout by a wet automatic sprinkler system designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems. Cooking Facilities CFR(s): NFPA 101 Cooking Facilities Cooking equipment is protected in accordance with NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations, unless: * residential cooking equipment (i.e., small appliances such as microwaves, hot plates, toasters) are used for food warming or limited cooking in accordance with 18.3.2.5.2, 19.3.2.5.2 * cooking facilities open to the corridor in smoke compartments with 30 or fewer patients comply with the conditions under 18.3.2.5.3, 19.3.2.5.3, or * cooking facilities in smoke compartments with			K 324			11/13/20

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

10/27/2020

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/02/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355051	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/30/2020
NAME OF PROVIDER OR SUPPLIER HATTON PRAIRIE VILLAGE			STREET ADDRESS, CITY, STATE, ZIP CODE 950 DAKOTA AVE HATTON, ND 58240		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 324	Continued From page 1 30 or fewer patients comply with conditions under 18.3.2.5.4, 19.3.2.5.4. Cooking facilities protected according to NFPA 96 per 9.2.3 are not required to be enclosed as hazardous areas, but shall not be open to the corridor. 18.3.2.5.1 through 18.3.2.5.4, 19.3.2.5.1 through 19.3.2.5.5, 9.2.3, TIA 12-2 This REQUIREMENT is not met as evidenced by: The facility failed to install cooking equipment in accordance with NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations. A readily accessible means for manual activation shall be located between 1067 mm and 1219 mm (42 in. and 48 in.) above the floor, be accessible in the event of a fire, be located in a path of egress, and clearly identify the hazard protected. 19.3.2.5.1, 9.2.3, NFPA 96 10.5.1. Observation determined the manual actuation device for the fire-extinguishing system serving the Kitchen exhaust hood was mounted at a height of more than forty-eight (48) inches above the floor. The manual pull was 61 inches above the floor. Failure to inspect, maintain, and install the wet chemical extinguishing system in accordance with NFPA 96 increases the risk of injury or death due to fire.	K 324	1. How corrective action will be accomplished. We will install a manual pull station/actuation device for the fire-extinguishing system serving the kitchen exhaust hood between 42" and 48" above the floor of the kitchen. 2. How facility will identify other portions of the facility having the potential to be affected by the same deficient practice. Our facility has no other kitchen hood with a wet chemical extinguishing system. No other portions of the facility have the potential to be affected by this deficient practice. 3. What measures will be put into place to ensure that the deficient practice will not occur.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/02/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355051	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/30/2020
NAME OF PROVIDER OR SUPPLIER HATTON PRAIRIE VILLAGE			STREET ADDRESS, CITY, STATE, ZIP CODE 950 DAKOTA AVE HATTON, ND 58240		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 324	Continued From page 2 This deficiency affected one (1) of one (1) wet chemical extinguishing system in the facility.	K 324	Installation of a manual pull station/actuation device for the kitchen hood between 42" and 48" above the floor ensures the deficient practice will not reoccur. 4. How the facility will monitor its corrective action to ensure the deficient practice is being corrected and will not reoccur. No monitoring is required. Once the manual pull station/actuation device for the kitchen hood is properly installed the deficient practice cannot reoccur. 5. Completion date: November 13, 2020		