

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/23/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - KNIFE RIVER CARE CENTER B. WING _____		(X3) DATE SURVEY COMPLETED 04/22/2013
NAME OF PROVIDER OR SUPPLIER KNIFE RIVER CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 118 22ND ST NE BEULAH, ND 58523		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	INITIAL COMMENTS This survey used the 2000 edition of NFPA 101, Life Safety Code, Chapter 18 New Health Care Occupancies in compliance with 42 CFR 483.70(a). The facility is located in a one-story building of Type V (111) construction. The building is equipped with an automatic wet and dry sprinkler system with quick response sprinklers designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems. Note: At the conclusion of the 04/22/2013 Life Safety Code survey, it was determined the facility was in compliance with the provisions of NFPA 101, Life Safety Code.	K 000			
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE			TITLE		(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.