

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/31/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355114	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 12/14/2009
NAME OF PROVIDER OR SUPPLIER NORTH DAKOTA VETERANS HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 1600 VETERANS DRIVE LISBON, ND 58054		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	INITIAL COMMENTS This survey used the 2000 edition of NFPA 101, Life Safety Code, Chapter 19 Existing Health Care Occupancies in compliance with 42 CFR 483.70(a) and NDAC 33-07-04.2-09(1)(c). The facility is located in a three-story building of Type II (111) construction. The nursing facility occupies the basement and first floor of the main building which is protected throughout with an approved, supervised wet automatic sprinkler system in accordance with the 1999 edition of NFPA 13, Standard for the Installation of Sprinkler Systems. Attached to the main building is a three-story basic care facility of Type II (111) construction with a full basement and a one story solarium of Type V (111) construction. The basic care and the solarium are separated from the main building by fire barriers having a two-hour fire resistance rating. At the conclusion of the LSC survey it was determined the facility was in compliance with the standards.	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.