

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/20/2020
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355114		(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - NORTH DAKOTA VETERANS HOME B. WING _____		(X3) DATE SURVEY COMPLETED 04/08/2019	
NAME OF PROVIDER OR SUPPLIER NORTH DAKOTA VETERANS HOME				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 VETERANS DRIVE LISBON, ND 58054			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS This survey used the 2012 edition of NFPA 101, Life Safety Code, Chapter 19-Existing Health Care Occupancies and the 2012 edition of NFPA 99, Health Care Facilities Code in compliance with 42 CFR 483.70(a)(b). The findings that follow demonstrate noncompliance with these standards. The facility was located in a one-story building of Type II (000) construction that was protected with an automatic sprinkler system designed to meet the requirements of NFPA 13, Standard for the Installation of Sprinkler Systems. A penthouse containing mechanical equipment was located above Sections A and D. An occupancy separation wall having a two-hour fire resistance rating provided a separation from the basic care building that was attached to the east and north sides of the building.			K 000			
K 712 SS=D	Fire Drills CFR(s): NFPA 101 Fire Drills Fire drills include the transmission of a fire alarm signal and simulation of emergency fire conditions. Fire drills are held at expected and unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Where drills are conducted between 9:00 PM and 6:00 AM, a coded announcement may be used instead of audible alarms. 19.7.1.4 through 19.7.1.7			K 712			6/1/19

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

06/06/2019

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/20/2020
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355114	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - NORTH DAKOTA VETERANS HOME B. WING _____		(X3) DATE SURVEY COMPLETED 04/08/2019
NAME OF PROVIDER OR SUPPLIER NORTH DAKOTA VETERANS HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 1600 VETERANS DRIVE LISBON, ND 58054		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 712	Continued From page 1 This REQUIREMENT is not met as evidenced by: The facility failed to conduct fire drills as required. Fire drill records review determined no fire drills were conducted on the Night Shift during the third quarter of 2018. Failure to conduct fire drills as required increases the risk of death or injury due to fire. The deficiency affected one (1) of twelve (12) drills in the past year.	K 712			