

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/14/2010
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355101	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - DAKOTA ALPHA B. WING _____	(X3) DATE SURVEY COMPLETED 07/12/2010
---	--	---	--

NAME OF PROVIDER OR SUPPLIER DAKOTA ALPHA	STREET ADDRESS, CITY, STATE, ZIP CODE 1303 27TH STREET NW MANDAN, ND 58554
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------------	--	---------------------	--	----------------------------

K 000 INITIAL COMMENTS

The 2000 edition of NFPA 101, Life Safety Code, Chapter 18-New Health Care Occupancies, was used for this survey in compliance with 42CFR483.70(a).

The facility is located in a one-story building of Type V (111) construction with a wet automatic sprinkler system designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems.

The facility was determined to be in compliance with the minimum requirements of the 2000 Life Safety Code.

K 000

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.