

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTIONS		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355106		(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - MILLER POINE, A... B. WING		(X3) DATE SURVEY COMPLETED 01/12/2026	
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY MILLER POINTE A PROSPERA CO				STREET ADDRESS, CITY, STATE, ZIP CODE 3500 21ST ST SE , MANDAN, North Dakota, 58554			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K0000	INITIAL COMMENTS This survey used the 2012 edition of NFPA 101, Life Safety Code, Chapter 19-Existing Health Care Occupancies and the 2012 edition of NFPA 99, Health Care Facilities Code in compliance with 42 CFR 483.70(a)(b). The findings that follow demonstrate noncompliance with these standards. The facility was located in a one-story building of Type V (111) construction. The building was protected throughout with a wet and dry automatic fire sprinkler system designed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems.			K0000			01/16/2026
K0921 SS = F Bldg. 02	Electrical Equipment - Testing and Maintenance CFR(s): NFPA 101 Electrical Equipment - Testing and Maintenance Requirements The physical integrity, resistance, leakage current, and touch current tests for fixed and portable patient-care related electrical equipment (PCREE) is performed as required in 10.3. Testing intervals are established with policies and protocols. All PCREE used in patient care rooms is tested in accordance with 10.3.5.4 or 10.3.6 before being put into service and after any repair or modification. Any system consisting of several electrical appliances demonstrates compliance with NFPA 99 as a complete system. Service manuals, instructions, and procedures provided by the manufacturer include information as required by 10.5.3.1.1 and are considered in the development of a program for electrical equipment maintenance. Electrical equipment instructions and maintenance manuals are readily available, and safety labels and condensed operating instructions on the appliance are legible. A record of electrical equipment tests, repairs, and modifications is maintained for a period of time to demonstrate compliance in accordance with the facility's policy. Personnel responsible for the			K0921	Each bed, IV pump, feeding pump, and air bed pumps received a complete electrical safety inspection and testing by maintenance personnel by 1/23/26. Any equipment, including beds found to be non-compliant, is either repaired, retested or removed from service until compliance is verified. Documentation of electrical testing is included in our TELs maintenance safety log upon completion. Our TELs maintenance system has been updated to include an annual electrical testing inspection for beds, IV pumps, feeding pumps, and air bed pumps. The Environmental service director conducted a facility-wide inventory of all patient-care related electrical equipment to ensure compliance with NFPA 99. Quality coordinator or her designee will audit electrical safety inspection and testing form monthly x1. QA committee will review with any further recommendations to be followed.		01/23/2026

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See reverse for further instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
---	-------	-----------

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTIONS		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355106		(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - MILLER POINE, A... B. WING		(X3) DATE SURVEY COMPLETED 01/12/2026	
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY MILLER POINTE A PROSPERA CO				STREET ADDRESS, CITY, STATE, ZIP CODE 3500 21ST ST SE , MANDAN, North Dakota, 58554			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K0921 SS = F Bldg. 02	Continued from page 1 testing, maintenance and use of electrical appliances receive continuous training. 10.3, 10.5.2.1, 10.5.2.1.2, 10.5.2.5, 10.5.3, 10.5.6, 10.5.8 This STANDARD is NOT MET as evidenced by: The facility failed to test all Patient-Care Related Electrical Equipment (PCREE) in use throughout the facility. Record review and interview with staff determined no testing of electric resident beds in use throughout the facility was completed, as required by NFPA 99, Health Care Facilities Code. Failure to inspect, test and maintain Patient-Care Related Electrical Equipment (PCREE) in accordance with NFPA 99 increases the risk of death or injury due to fire. The deficiency affected all electric resident beds in use throughout the facility.			K0921			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTIONS		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355106		(X2) MULTIPLE CONSTRUCTION A. BUILDING B. WING		(X3) DATE SURVEY COMPLETED 01/12/2026	
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY MILLER POINTE A PROSPERA CO				STREET ADDRESS, CITY, STATE, ZIP CODE 3500 21ST ST SE , MANDAN, North Dakota, 58554			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E0000	Initial Comments A recertification survey conducted on 01/12/2026 found Good Samaritan Society Miller Pointe A Prospera Community in compliance with the requirements of 483.73 Long-Term Care Facilities Emergency Preparedness.			E0000			01/16/2026

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See reverse for further instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
---	-------	-----------