

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/28/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355106		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/28/2016	
NAME OF PROVIDER OR SUPPLIER SANFORD HEALTH CONTINUING CARE CENTER OFF COLLINS				STREET ADDRESS, CITY, STATE, ZIP CODE 201 14TH ST NW MANDAN, ND 58554			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS This survey used the 2000 edition of NFPA 101, Life Safety Code, Chapter 19 Existing Health Care Occupancies in compliance with 42 CFR 483.70(a). The findings that follow demonstrate noncompliance with these requirements. The facility was located in a one-story building of Type II (000) construction on a concrete slab. The building was protected throughout by a wet automatic sprinkler system designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems.			K 000			
K 052 SS=F	NFPA 101 LIFE SAFETY CODE STANDARD A fire alarm system required for life safety shall be, tested, and maintained in accordance with NFPA 70 National Electric Code and NFPA 72 National Fire Alarm Code and records kept readily available. The system shall have an approved maintenance and testing program complying with applicable requirement of NFPA 70 and 72. 9.6.1.4, 9.6.1.7, This STANDARD is not met as evidenced by: Visual inspection frequencies and specific testing and maintenance frequencies for fire alarm systems and smoke detection systems are dictated by the prescriptive requirements of NFPA 72, National Fire Alarm Code (Chapter 10-Inspection, Testing and Maintenance Tables 10.3.1, 10.4.2.2 and 10.4.3). This code identifies specific inspection, testing and maintenance frequencies and methods. Functional testing of the fire alarm system and smoke detectors is to be completed initially during the acceptance test and at least on an annual basis thereafter. Visual inspections are to			K 052	A maintenance program will be established to have an annual inspection of the fire alarm and smoke detection system by an outside company in accordance with NFPA 72 National Fire Alarm Code. An annual inspection of the fire alarm and smoke detection system is scheduled for October 25 2016. Sanford Health Continuing Care Center off Collins will conduct monthly visual observations of the fire panel by maintenance personnel and document any findings. Facility Quality Coordinator will audit fire drill report monthly x 12 months. Service		10/25/16

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

10/03/2016

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/28/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355106	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/28/2016
NAME OF PROVIDER OR SUPPLIER SANFORD HEALTH CONTINUING CARE CENTER OFF COLLINS			STREET ADDRESS, CITY, STATE, ZIP CODE 201 14TH ST NW MANDAN, ND 58554		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 052	Continued From page 1 be conducted initially during the acceptance test and on a semiannual basis thereafter. Sensitivity testing of smoke detectors is to be completed for all smoke detectors during the first year in service, and the alternate year following. After the second required calibration test, if the detector has remained within its listed and marked sensitivity range, the length of time between calibration tests may be extended, not to exceed five years. Record review determined the facility failed to test the fire alarm and smoke detection system annually in accordance with NFPA 72 National Fire Alarm Code. Records review determined the annual fire alarm system inspection was last completed on 07/09/2015 by an outside company. Failure to test the fire alarm system as required by NFPA 72 increases the risk of injury or death due to fire. This deficiency affects the fire alarm and smoke detection system which serves the entire building.	K 052	work will be performed by a fire protection company if observations note issues with fire panel.		
K 144 SS=F	NFPA 101 LIFE SAFETY CODE STANDARD Generators inspected weekly and exercised under load for 30 minutes per month and shall be in accordance with NFPA 99 and NFPA 110. 3-4.4.1 and 8-4.2 (NFPA 99), Chapter 6 (NFPA 110) This STANDARD is not met as evidenced by: A remote annunciator, storage battery powered, shall be provided to operate outside of the	K 144	Facility will ensure the emergency generator is in compliance with NFPA 99,	2/1/17	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/28/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355106	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/28/2016
NAME OF PROVIDER OR SUPPLIER SANFORD HEALTH CONTINUING CARE CENTER OFF COLLINS			STREET ADDRESS, CITY, STATE, ZIP CODE 201 14TH ST NW MANDAN, ND 58554		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 144	Continued From page 2 generating room in a location readily observed by operating personnel at a regular work station. NFPA 99 3-4.1.1.15 The facility failed to ensure the emergency generator was in compliance with NFPA 99, Standard for Health Care Facilities. Observation determined there was no remote annunciator located outside of the Generator Room at a work site readily observable by personnel. Failure to ensure emergency generators are in compliance with NFPA 99 increases the risk of death or injury due to fire. The deficiency affected one (1) of one (1) emergency generator which provides all emergency power to the facility.	K 144	Standard for Health Care Facilities. Our new building will include a remote annunciator located outside of the Generator Room that is readily observable by personnel.		