

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/24/2011
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION MAR 7 2011	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355094	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/22/2011
--	--	---	--

DIVISION OF LIFE SAFETY

NAME OF PROVIDER OR SUPPLIER

GOOD SAMARITAN SOCIETY - MOHALL

STREET ADDRESS, CITY, STATE, ZIP CODE

**602 E MAIN ST
MOHALL, ND 58761**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS This survey used the 2000 edition of NFPA 101, Life Safety Code, Chapter 19 Existing Health Care Occupancies in compliance with 42 CFR 483.70(a). The facility is located in a one-story building of Type V (000) construction built in 1977 with an addition in 1996. The building is equipped with a wet automatic sprinkler system designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems.	K 000		
K 052 SS=F	NFPA 101 LIFE SAFETY CODE STANDARD A fire alarm system required for life safety is installed, tested, and maintained in accordance with NFPA 70 National Electrical Code and NFPA 72. The system has an approved maintenance and testing program complying with applicable requirements of NFPA 70 and 72. 9.6.1.4 This STANDARD is not met as evidenced by: The facility failed to ensure the fire alarm system was in compliance with NFPA 72. Fire alarm connections to the light and power service must be on a dedicated branch circuit. The circuit and connections must be mechanically protected. Circuit disconnection means must have a red marking, be accessible only to authorized personnel, and be identified as Fire	K 052		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/24/2011
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355094	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/22/2011
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - MOHALL			STREET ADDRESS, CITY, STATE, ZIP CODE 602 E MAIN ST MOHALL, ND 58761		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 052	Continued From page 1 Alarm Circuit Control. Observation determined the facility failed to provide a locking device on the fire alarm electrical circuit breaker. The electrical panel with the fire alarm electrical breaker was located in the Mechanical Room.	K 052	1.) Circuit breaker locking device will be placed on the fire alarm electrical panel breakers. 2.) There are no other areas with the potential to be affected by this practice.		
K 062 SS=F	NFPA 101 LIFE SAFETY CODE STANDARD Required automatic sprinkler systems are continuously maintained in reliable operating condition and are inspected and tested periodically. 19.7.6, 4.6.12, NFPA 13, NFPA 25, 9.7.5 This STANDARD is not met as evidenced by: Testing frequencies for automatic sprinkler systems range from quarterly to annually. Inspection frequencies can be as often as weekly to as long as annually. The frequencies for testing, inspection and maintenance of automatic sprinkler systems are dictated by the requirements as outlined by Table 5-1 of NFPA 25, Standard for the Inspection, Testing and Maintenance of Water-based Fire Protection Systems. NFPA 25 requires the facility to complete, maintain and make available to the authority having jurisdiction copies of records which indicate the procedure performed, by whom, the results and the date. These records are to be retained for the life of the system. The automatic sprinkler system is required to have specified maintenance. Sprinkler record review determined the facility failed to document the flow and pressure data observed for the quarterly tests.	K 062	3.) The electrical contractor will educate designated staff the appropriate application of the circuit breaker locking device. 4.) QA/CQI committee will conduct monthly audits x 3 months then quarterly x 1 year. 5.) Date of completion	3/31/2011	
			1.) Flow and pressure data will be recorded on the automatic sprinkler system quarterly test log. 2.) There are no other areas with the potential to be affected by this practice. 3.) Contract vendor will provide education to designated staff on conducting quarterly test of flow and pressure. 4.) QA/CQI will review documentation monthly x 3 months then quarterly x 1 year. 5.) Completion date	3/31/2011	

PRINTED: 02/24/2011
FORM APPROVED
OMB NO. 0938-0391

FORM CMS-2567(02-99) Previous Versions Obsolete Event ID: Z8M921 Facility ID: ND163 If continuation sheet Page 3 of 3