

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/24/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355076	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - NORTHWOOD DEACONE! B. WING _____		(X3) DATE SURVEY COMPLETED 07/27/2011
NAME OF PROVIDER OR SUPPLIER NORTHWOOD DEACONESS HEALTH CNT			STREET ADDRESS, CITY, STATE, ZIP CODE 4 N PARK ST NORTHWOOD, ND 58267		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS This survey used the 2000 edition of NFPA 101, Life Safety Code, Chapter 19 Existing Health Care Occupancies in compliance with 42 CFR 483.70(a). Building 2 of 2 was a one story building of Type III (200) construction with a wet automatic fire sprinkler system designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems. The hospital was built and attached to the north of the nursing facility (Building 1 of 2) in 1970. The north wing of the hospital was converted to a special care unit in 1993. Note: At the conclusion of the 07/27/11 Life Safety Code survey, it was determined the facility was in compliance with the provisions of NFPA 101, Life Safety Code.	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.