

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/30/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355095		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/14/2019	
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - OAKES				STREET ADDRESS, CITY, STATE, ZIP CODE 213 N 9TH ST OAKES, ND 58474			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS			K 000			
K 511 SS=E	This survey used the 2012 edition of NFPA 101, Life Safety Code, Chapter 19-Existing Health Care Occupancies and the 2012 edition of NFPA 99, Health Care Facilities Code in compliance with 42 CFR 483.70(a)(b). The findings that follow demonstrate noncompliance with these standards. The facility was located in a one-story building of Type V (000) construction with a dry automatic fire sprinkler system designed to meet the requirements of NFPA 13, Standard for the Installation of Sprinkler Systems. Utilities - Gas and Electric CFR(s): NFPA 101 Utilities - Gas and Electric Equipment using gas or related gas piping complies with NFPA 54, National Fuel Gas Code, electrical wiring and equipment complies with NFPA 70, National Electric Code. Existing installations can continue in service provided no hazard to life. 18.5.1.1, 19.5.1.1, 9.1.1, 9.1.2 This REQUIREMENT is not met as evidenced by: Ground-fault circuit-interruption for personnel shall be provided as required. The ground-fault circuit-interrupter shall be installed in a readily accessible location. All 125-volt, single-phase, 15- and 20-ampere receptacles located in bathrooms, kitchens and where receptacles are installed within 6 ft. of the outside edge of the			K 511	1. Electrical Receptacles with ground fault will be installed in the bathrooms listed: resident, women & men in the center area & west staff, dietary, therapy. Also, on the 800 wing janitor closet, dining room sink and some of the kitchen receptacles according to vender ☐s		6/15/19

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

05/22/2019

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/30/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355095	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/14/2019
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - OAKES			STREET ADDRESS, CITY, STATE, ZIP CODE 213 N 9TH ST OAKES, ND 58474		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 511	Continued From page 1 sink shall have ground-fault circuit-interrupter protection for personnel. 19.5.1.1, 9.1.2, NFPA 70, 210.8, 210.8(B)(1), 210.8(B)(2), 210.8(B)(5) The facility failed to ensure electrical wiring and electrical equipment met the requirements of NFPA 70, National Electrical Code. Observation determined: 1) One (1) electrical receptacle in the Center Resident Bathroom was not ground-fault circuit-interrupter protected. 2) One (1) electrical receptacle in the Center Men's Bathroom was not ground-fault circuit-interrupter protected. 3) One (1) electrical receptacle in the Center Women's Bathroom was not ground-fault circuit-interrupter protected. 4) One (1) electrical receptacle in the West Staff Bathroom was not ground-fault circuit-interrupter protected. 5) One (1) electrical receptacle in the Dietary Bathroom was not ground-fault circuit-interrupter protected. 6) Two (2) electrical receptacles in the Therapy Bathroom were not ground-fault circuit-interrupter protected. 7) One (1) electrical receptacle in the 800 Wing Janitor Closet within 6 ft. of a floor sink was not ground-fault circuit-interrupter protected.	K 511	schedule. 2. This has a potential to affect & increase the risk of harm to an individual or the facility in case of a fire. 3. Educations was given by surveyor to the maintenance supervisor regarding the changes to the new code to meet these new requirements within the NFPA 70 code. 4. The Maintenance supervisor will do an audit to see if any other rooms or places that need ground fault electrical receptacles replaced to meet this requirement. This audit will be given to the QA Coordinator or designee and discussed at our Monthly QA Meeting. We will conduct an audit monthly X 2 and quarterly X 2 then as deemed necessary by the QA committee. 5. Completion date. June 15th, 2019		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/30/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355095	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/14/2019
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - OAKES			STREET ADDRESS, CITY, STATE, ZIP CODE 213 N 9TH ST OAKES, ND 58474		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 511	Continued From page 2 8) One (1) electrical receptacle in the Dining Room within 6 ft. of a sink was not ground-fault circuit-interrupter protected. 9) Three (3) electrical receptacles in the Kitchen were not ground-fault circuit-interrupter protected. Failure to provide electrical wiring and equipment in accordance with NFPA 70 increases the risk of injury or death due to fire. The deficiency affected twelve (12) of numerous receptacles in the facility.	K 511			
K 712 SS=F	Fire Drills CFR(s): NFPA 101 Fire Drills Fire drills include the transmission of a fire alarm signal and simulation of emergency fire conditions. Fire drills are held at expected and unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Where drills are conducted between 9:00 PM and 6:00 AM, a coded announcement may be used instead of audible alarms. 19.7.1.4 through 19.7.1.7 This REQUIREMENT is not met as evidenced by: The facility failed to conduct fire drills as required. Fire drill records review determined fire drills did not include the simulation of an emergency phone call to the fire department during the months of May, June, August, September,	K 712	1. We received a new fire drill form that includes the simulation of an emergency phone call to the fire department on a monthly base. 2. This could increase the risk of injury during a fire throughout the facility. 3. Education was given by the surveyor	5/15/19	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/30/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355095	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/14/2019
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - OAKES			STREET ADDRESS, CITY, STATE, ZIP CODE 213 N 9TH ST OAKES, ND 58474		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 712	Continued From page 3 October, November and December 2018, and January, February and March 2019. Failure to conduct fire drills as required increases the risk of death or injury due to fire. The deficiency affected ten (10) of twelve (12) drills in the past year.	K 712	to the maintenance supervisor regarding the changes to the new code. 4. An audit will be conducted monthly X 3 then quarterly X 2 then as deemed necessary by the QA committee. The QA Coordinator or designee will do the audit and discussed at our QA meeting. 5. Completion date May 15th 2019.		