


DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/03/2011
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION AUG 10 2011	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355033	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/18/2011
---	--	---	--

NAME OF PROVIDER OR SUPPLIER ST CATHERINES LIVING CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 1307 N 7TH ST WAHPETON, ND 58075
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS This survey used the 2000 edition of NFPA 101, Life Safety Code, Chapter 19-Existing Health Care Occupancies in compliance with 42CFR 483.70(a). The original building was one-story of Type II (111) construction. Additions attached to the structure were of Type V (000) construction with a wet automatic sprinkler system designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems. A Fire Safety Evaluation System (FSES) was conducted as a result of the 7/18/11 Life Safety Code survey. The FSES was specifically used as an alternative safety method for Tag K 024 - Travel Distance Within Smoke Compartment and K 056 - Combustible Canopy Not Sprinklered. The facility passes the FSES. Note: CMS requires unsprinklered long term care facilities to install an approved, supervised automatic sprinkler system in accordance with the 1999 edition of NFPA 13, Standard for the Installation of Sprinkler Systems throughout the buildings by August 13, 2013.	K 000		
K 024 SS=B	NFPA 101 LIFE SAFETY CODE STANDARD The smoke compartments do not exceed 22,500 square feet and the travel distance to and from any point to reach a door in the required smoke barrier does not exceed 200 feet. 19.3.7.1	K 024		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE 	TITLE Director Plant Operations	(X6) DATE 8/09/11
---	---	-----------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/03/2011
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355033	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/18/2011
NAME OF PROVIDER OR SUPPLIER ST CATHERINES LIVING CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 1307 N 7TH ST WAHPETON, ND 58075		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 024	Continued From page 1 This STANDARD is not met as evidenced by: The facility failed to ensure the travel distance to reach a door in the required smoke barrier did not exceed 200 feet. Observation determined the 500/600 Wing smoke compartment exceeded the maximum 200 feet travel distance to reach the nearest smoke barrier.	K 024	A Fire Safety Evaluation System (FSES) was conducted as a result of the 7/18/11 Life Safety Code survey. The FSES was specifically used as an alternative safety method for Tag K 024 - Travel Distance Within Smoke Compartment. The facility passes the FSES.		
K 056 SS=B	NFPA 101 LIFE SAFETY CODE STANDARD If there is an automatic sprinkler system, it is installed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems, to provide complete coverage for all portions of the building. The system is properly maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems. It is fully supervised. There is a reliable, adequate water supply for the system. Required sprinkler systems are equipped with water flow and tamper switches, which are electrically connected to the building fire alarm system. 19.3.5 This STANDARD is not met as evidenced by: The facility failed to ensure all areas were protected by the automatic fire sprinkler system. Observation determined a combustible canopy greater than 48 inches in depth located at the exterior of the south exit of the Dietary Service Area was not protected by the sprinkler system.	K 056	A Fire Safety Evaluation System (FSES) was conducted as a result of the 7/18/11 Life Safety Code survey. The FSES was specifically used as an alternative safety method for Tag K 056 - Automatic Sprinkler System Coverage. The facility passes the FSES.		