

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/03/2020
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355057		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/24/2019	
NAME OF PROVIDER OR SUPPLIER PEMBILIER NURSING CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 500 DELANO AVE WALHALLA, ND 58282			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS This survey used the 2012 edition of NFPA 101, Life Safety Code, Chapter 18 New Health Care Occupancies and Chapter 19 Existing Health Care Occupancies and the 2012 edition of NFPA 99, Health Care Facilities Code in compliance with 42 CFR 483.70(a)(b). The facility was located in a one-story building of Type V (000) construction surveyed using Chapter 19 Existing Health Care Occupancies. Two one-story additions of Type V (111) construction were attached to the south and east side of the existing building in 2018 and were separated from the existing building by walls having two-hour fire resistance ratings. The 2018 additions were surveyed using Chapter 18 New Health Care Occupancies. The entire facility was protected by a wet and dry automatic fire sprinkler system designed to meet the requirements of NFPA 13, Standard for the Installation of Sprinkler Systems. A garage and assisted living apartments were attached to the southwest end of the facility. A two-hour fire rated wall assembly separated the facility from the adjoining garage and assisted living building. Observation and records review determined the facility to be in compliance with the minimum requirements of the 2012 Life Safety Code and Health Care Facilities Code.			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

09/30/2019

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.