

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/31/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 355124	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - SHEYENNE CROSSINGS CARE CENTER TCU B. WING _____		(X3) DATE SURVEY COMPLETED 12/30/2014
NAME OF PROVIDER OR SUPPLIER SHEYENNE CROSSINGS CARE CENTER/TCU			STREET ADDRESS, CITY, STATE, ZIP CODE 125 13TH AVENUE WEST WEST FARGO, ND 58078		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	INITIAL COMMENTS This survey used the 2000 edition of NFPA 101, Life Safety Code, Chapter 18 New Health Care Occupancies in compliance with 42 CFR 483.70(a). The facility was located in two buildings that were separated by two-hour fire resistive construction. The building that houses the residents and the administration staff was a one-story building of Type V (111) construction. The other building housing the building services and Chapel was a two-story building of Type II (111) construction. A two-story apartment/basic care building was connected to the northwest corner of the two-story building with a two-hour fire resistive occupancy separation. The buildings were equipped with a wet and dry automatic sprinkler system with quick response sprinklers designed to meet the requirements of NFPA 13, Standard for Installation of Sprinkler Systems. Based on observation and records reviewed the facility was determined to be in compliance with the provisions of NFPA 101, Life Safety Code.	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.