

Division of Health Improvement

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 2288	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R-C 09/01/2023
NAME OF PROVIDER OR SUPPLIER BEEHIVE HOMES OF BERNALILLO		STREET ADDRESS, CITY, STATE, ZIP CODE 200 SHERIFFS POSSE ROAD BERNALILLO, NM 87004		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 000}	Initial Comments The following deficiencies were cited during a Follow-up/Revisit survey completed on [REDACTED]/23 for the state requirements of NMAC 7.8.2, Regulations for Assisted Living Facilities for Adults. Census: 11	{A 000}	The manager will ensure that an accessible and functional telephone will be available in case of an emergency and a list of emergency contact phone numbers will be posted near the public phone for residents, family, and visitors to use including the fire department, police department, ambulance services, and poison control.	09/01/23
{A 031}	7 NMAC 8.2.31 Handling of Emergencies HANDLING OF EMERGENCIES: A. Upon admission, each resident or surrogate decision maker shall designate a primary care practitioner (PCP) to be called in case of a medical necessity. Each resident or representative shall also designate a concerned person to be called in case of an emergency. The facility shall establish a policy to secure medical assistance if the resident's own physician is not available. In the event of an illness or an injury to the resident, the PCP or a physician extender shall be notified by the facility. B. The facility shall have a first aid kit that contains at a minimum, gauze, adhesive tape, antiseptic ointment and bandages for emergencies. The first aid kit shall be kept in a designated, easily accessible place within the facility. C. An easily accessible and functional telephone shall be available in each facility for summoning help in case of an emergency. A pay telephone does not fulfill this requirement. D. A list of emergency numbers including: fire department, police department, ambulance services and poison control shall be posted near each public telephone in the facility. [7.8.2.31 NMAC - Rp, 7.8.2.32 NMAC, 01/15/2010]	{A 031}	Corrected on 09/01/23 Moved the phone to the main common area and posted an emergency contact list for residents, families, and visitors to meet the needs of all emergency numbers	

Division of Health Improvement

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE



10/09/2023

Division of Health Improvement

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 2288	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R-C 09/01/2023
NAME OF PROVIDER OR SUPPLIER BEEHIVE HOMES OF BERNALILLO		STREET ADDRESS, CITY, STATE, ZIP CODE 200 SHERIFFS POSSE ROAD BERNALILLO, NM 87004		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 031}	Continued From page 1 This REQUIREMENT is not met as evidenced by: 7.8.2.31 D Based on observation and interview, the facility failed to ensure that a list of emergency contact phone numbers was posted near the public phone for residents, family, and visitors to use including the phone numbers for: fire department, police department, ambulance services, and poison control. This deficient practice could likely result in all [REDACTED] [REDACTED] residents listed on the resident census, provided by Administrator on [REDACTED]/23, to be at risk of harm, injury, or death if there is a delay in receiving emergency medical care and services because there was not a list of emergency numbers posted next to the public phone. The findings are: A. On [REDACTED]/23 at 1:12 pm, during an observation of the public telephone in the kitchen area, there were no emergency phone numbers posted near the telephone. B. On [REDACTED]/23 at 1:12 pm, during an interview, the Administrator confirmed there were no emergency numbers posted near the public telephone in the kitchen.	{A 031}		
{A 045}	7 NMAC 8.2.45 Water WATER: Pursuant to the current New Mexico drinking water requirements, 7.6.2.9 NMAC. A. The water supply system shall be constructed,	{A 045}		

Division of Health Improvement

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 2288	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R-C 09/01/2023
NAME OF PROVIDER OR SUPPLIER BEEHIVE HOMES OF BERNALILLO		STREET ADDRESS, CITY, STATE, ZIP CODE 200 SHERIFFS POSSE ROAD BERNALILLO, NM 87004		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 045}	Continued From page 2 protected, operated and maintained in conformance with applicable local, state and federal laws, ordinances and regulations. B. Where a facility is supplied by its own water system, the system shall meet the sampling and construction requirement of a non-community water system as defined by the current New Mexico drinking water requirements. C. All water that is not piped into the facility directly from a public water supply system shall be from an approved source, disinfected, transported, handled, stored and dispensed in a sanitary manner. Such water shall be prevented from entering potable water systems by appropriate cross connection and backflow prevention devices. D. Hot and cold running water, under pressure shall be provided in all areas where food is prepared and where equipment and utensils are washed, sinks, lavatories, washrooms and laundries. E. The hot water temperature that is accessible to residents shall be maintained at a minimum of ninety-five (95) degrees fahrenheit and a maximum of one hundred ten (110) degrees fahrenheit. Hot water in excess of one hundred ten (110) degrees fahrenheit is permitted in kitchen and laundry areas, provided that residents are supervised in order to prevent injury. [7.8.2.45 NMAC - Rp, 7.8.2.46 NMAC, 01/15/2010] This REQUIREMENT is not met as evidenced by: 7.8.2.45 (E) Based on observation, record review, and interview, the facility failed to ensure hot water	{A 045}	The house manager will ensure that the hot water temperature that is accessible to residents shall be maintained at a minimum of ninety-five (95) degrees Fahrenheit and a maximum of one hundred ten (110) degrees Fahrenheit. Hot water in excess of one hundred ten (110) degrees Fahrenheit is permitted in kitchen and laundry areas, provided that residents are supervised. Adjusted temperature on 09/22/23 Turned down hot water heater thermostat to meet the requirements for temperature The house manager will monitor temperature.	09/22/23

Division of Health Improvement

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 2288	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R-C 09/01/2023
NAME OF PROVIDER OR SUPPLIER BEEHIVE HOMES OF BERNALILLO		STREET ADDRESS, CITY, STATE, ZIP CODE 200 SHERIFFS POSSE ROAD BERNALILLO, NM 87004		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 045}	Continued From page 3 temperatures in resident restrooms were maintained at a maximum of 110 degrees Fahrenheit (F). This deficient practice could likely result in the [REDACTED] residents listed on the census list provided by the Administrator on [REDACTED]/23, to be at risk of being injured and burned by water that is too hot. The findings are: A. On [REDACTED]/23 at 12:53 pm, during an observation of the bathroom sink in [REDACTED], the water temperature was observed to be at 140-degrees Fahrenheit (F). B. On [REDACTED]/23 at 12:53 pm, during an interview with resident in [REDACTED], [REDACTED] stated the water in the bathroom sink was a little bit hot and asked if it could be turned down a little bit. C. On [REDACTED] 8/23 at 1:16 pm, during an observation of the bathroom sink in empty [REDACTED], the water temperature was observed to be at 150-degrees F. D. On [REDACTED]/23 at 1:29 pm, during an interview with the Administrator, she confirmed the water temperatures in [REDACTED] were 150-degrees and 140-degrees F.	{A 045}		



09/22/2023