

Division of Health Improvement

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 2288	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R-C 01/03/2024
NAME OF PROVIDER OR SUPPLIER BEEHIVE HOMES OF BERNALILLO		STREET ADDRESS, CITY, STATE, ZIP CODE 200 SHERIFFS POSSE ROAD BERNALILLO, NM 87004		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 000}	Initial Comments The following deficiencies were cited during an onsite Revisit/Follow-up survey completed on [REDACTED]/24 for the state requirements of 7 NMAC 8.2, Regulations for Assisted Living for Adults. Resident Census is 13	{A 000}	The house manager will ensure that the hot water temperature that is accessible to residents shall be maintained at a minimum of ninety-five (95) degrees Fahrenheit and a maximum of one hundred ten (110) degrees Fahrenheit. Hot water in excess of one hundred ten (110) degrees Fahrenheit is permitted in kitchen and laundry areas, provided that residents are supervised.	2/28/2024
{A 045}	7 NMAC 8.2.45 Water WATER: Pursuant to the current New Mexico drinking water requirements, 7.6.2.9 NMAC. A. The water supply system shall be constructed, protected, operated and maintained in conformance with applicable local, state and federal laws, ordinances and regulations. B. Where a facility is supplied by its own water system, the system shall meet the sampling and construction requirement of a non-community water system as defined by the current New Mexico drinking water requirements. C. All water that is not piped into the facility directly from a public water supply system shall be from an approved source, disinfected, transported, handled, stored and dispensed in a sanitary manner. Such water shall be prevented from entering potable water systems by appropriate cross connection and backflow prevention devices. D. Hot and cold running water, under pressure shall be provided in all areas where food is prepared and where equipment and utensils are washed, sinks, lavatories, washrooms and laundries. E. The hot water temperature that is accessible to residents shall be maintained at a minimum of ninety-five (95) degrees fahrenheit and a maximum of one hundred ten (110) degrees fahrenheit. Hot water in excess of one hundred ten (110) degrees fahrenheit is permitted in	{A 045}	Maintenance will be contacted to check the compressor pump in the water heater. This is ensure that Water Temperature can be held at the required Fahrenheit. The house manager will monitor temperature.	

Division of Health Improvement
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE



(X6) DATE

01/11/2024

Division of Health Improvement

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 2288	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R-C 01/03/2024
NAME OF PROVIDER OR SUPPLIER BEEHIVE HOMES OF BERNALILLO		STREET ADDRESS, CITY, STATE, ZIP CODE 200 SHERIFFS POSSE ROAD BERNALILLO, NM 87004		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 045}	Continued From page 1 kitchen and laundry areas, provided that residents are supervised in order to prevent injury. [7.8.2.45 NMAC - Rp, 7.8.2.46 NMAC, 01/15/2010] This REQUIREMENT is not met as evidenced by: This is a repeat deficiency from survey dated [REDACTED]/23. 7.8.2.45 (E) Based on observation, record review, and interview, the facility failed to ensure hot water temperatures in resident restrooms were maintained at a maximum of 110 degrees Fahrenheit (F). This deficient practice could likely result in the [REDACTED] residents listed on the census list provided by the House Manager on [REDACTED]/24, to be at risk of being injured and burned by water that is too hot. The findings are: A. On [REDACTED]/24 at 8:28 am, during an observation (with the use of a digital thermometer) of the bathroom sink in [REDACTED], the water temperature was 154 degrees Fahrenheit (F). B. On [REDACTED]/24 at 8:35 am, during an interview with the House Manager, he confirmed (with the use of a digital thermometer) the water temperature in [REDACTED] was 154 degrees Fahrenheit (F). He confirmed that the facility's water heater is on setting "A" which is considered	{A 045}		

Division of Health Improvement

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 2288	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R-C 01/03/2024
NAME OF PROVIDER OR SUPPLIER BEEHIVE HOMES OF BERNALILLO		STREET ADDRESS, CITY, STATE, ZIP CODE 200 SHERIFFS POSSE ROAD BERNALILLO, NM 87004		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 045}	Continued From page 2 low heat. If they adjust the water heater lower, it affects other resident rooms. It shuts off the hot water completely in their restrooms. C. On [REDACTED]/24 at 8:37 am, during an observation (with the use of a digital thermometer) with the House Manager, the bathroom sink in [REDACTED] the water temperature was observed to be at 150 degrees Fahrenheit (F).	{A 045}		