



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Waller Road Home	Provider Number	001014
Address	4710 WALLER RD E,	Approval Status	Approved
City, State, Zip	Tacoma, WA 98443	Facility Type	Residential Care

On 06/09/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state and inspected by the state fire marshal's office, at least twelve planned and unannounced fire drills shall be held every year.

(1) Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions.

(2) A detailed written record of all fire drills shall be maintained and available for inspection.

(3) When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms.

Facility failed to provide fire drills for 2024

Next inspection scheduled on or after: 06/30/2026

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Gerilyn K. Arenas
Signature

GERILYN K. ARENAS Owner/Admin.
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0968

Signature