



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Country Meadow Village	Provider Number	001020
Address	1501 COLLINS RD ,	Approval Status	Approved
City, State, Zip	Sedro-Woolley, WA	Facility Type	Residential Care

On 10/28/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 199374 Here's a complaint of Fire Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	Complaint ref # 199374 At 1145 on 10/28/2025, DSFM Brown conducted complaint inspection for Country Meadow Village located at 1501 Collins Rd, Sedro-Woolley, WA 98284 to investigate complaint ref # 199374. I interviewed the Facility Maintenance Director. On 10/22/2025, at approximately 1330, a fire occurred at the electrical outlet where the steamer was plugged in. The circuit breaker tripped, and the fire was contained. The Sedro-Woolley Fire Department responded to the incident. To ensure the fire was completely extinguished within the wall, the Fire Department used a chainsaw on the exterior wall to remove the siding and expose the wiring. During this process, an electrical cable in the wall was accidentally cut, resulting in the loss of power to most of the kitchen appliances. An electrician was on-site on 10/24/2025, with an electrical permit to complete the necessary repairs. The steamer has since been properly hardwired to an electrical box. While the exterior wall still requires cosmetic repair, there is no remaining fire hazard. No injuries were report. No violations observed.
---	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Country Meadow Village	Provider Number	001020
Address	1501 COLLINS RD ,	Approval Status	Approved
City, State, Zip	Sedro-Woolley, WA	Facility Type	Residential Care

On 10/28/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement

Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Susan Cortez Maintenance
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037


Signature

This document was prepared by Residential Care Services for the Locator website.