



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Courtyard at Christa Shores	Provider Number 001041
Address 1600 NW CRISTA SHORES LN,	Approval Status Approved
City, State, Zip Silverdale, WA 98383	Facility Type Residential Care

On 07/11/2024 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint


COMPLAINT # 137270 Here's a complaint of electrical fire in light fixture Please include the answers to the following questions in your report in FDM. 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No	COMPLAINT # 137270 On July 11, 2024 a complaint investigation was conducted at Courtyard at Christa Shores located at 1600 NW Christa Shores Lane, Silverdale, WA 98383. An interview was conducted with facility staff. Fire occurred in bathroom of a resident unit. Staff responded and put out the fire with a portable fire extinguisher. There was a fire, suppression system did not activate, area of fire location was evacuated, there were no injuries, and fire department did respond.
--	---

Next inspection scheduled on or after:


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature


Print Name and Title Executive Director

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0087


Signature

Initials of Authorized Facility Representative: 