



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Mill Ridge Village
Address 607 28TH AVE ,
City, State, Zip Milton, WA

Provider Number 001073
Approval Status Approved
Facility Type Residential Care

On 8/12/2025 the Office of the State Fire Marshal conducted an inspection at your facility.


All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Jesse Howells Executive Director
Print Name and Title

Deputy State Fire Marshal Damon Roberson
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Mill Ridge Village	Provider Number	001073
Address	607 28TH AVE ,	Approval Status	Disapproved
City, State, Zip	Milton, WA 983549343	Facility Type	Residential Care

On 5/20/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Inspection and Maintenance

Opening protectives in fire-resistance-rated assemblies shall be inspected and maintained in accordance with NFPA 80. Opening protectives in smoke barriers shall be inspected and maintained in accordance with NFPA 80 and NFPA 105. Openings in smoke partitions shall be inspected and maintained in accordance with NFPA 105. Fire doors and smoke and draft control doors shall not be blocked, obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Opening protectives and smoke and draft control doors shall not be modified. (IFC 705.2 2021)	Findings during the reinspection were: Fire doors shall include the fire listed label and label all fire doors within the building.
--	--

2 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion. (IFC 904.13.5.2 2021)	Corrected
---	-----------



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Mill Ridge Village
Address 607 28TH AVE ,
City, State, Zip Milton, WA 983549343

Provider Number 001073
Approval Status Disapproved
Facility Type Residential Care


On 5/20/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after: 6/19/2025


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

Jesse Howells Executive Director
Print Name and Title

Deputy State Fire Marshal Damon Roberson
2803 156 AVE SE
Bellevue WA 98007
(360) 584-4392


Signature