



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Fairview Assisted Living Inc
Address 1617 Calsipel ,
City, State, Zip Spokane, WA 99205

Provider Number 001146
Approval Status Approved
Facility Type Residential Care

On 03/27/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 172662

Here's a complaint of a fire alarm.

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire? N/A
2. If the sprinklers were activated? N/A
3. If there was an evacuation / how many were evacuated? N/A
4. If there were injuries / how many? N/A
5. Did the fire department respond? Yes

A representative from the State Fire Marshals Office completed a complaint inspection at the Fairview Assisted Living Facility on 3/27/25 and 4/24/25.

An annual fire sprinkler testing/maintenance inspection was completed and it appears that a valve was not completely closed causing an alarm.

The fire department responded and cleared the fire sprinkler system. Patriot Fire came by and adjusted the valve for the dry system.

No violations cited.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

 Karen Simmons, RN Director of Nursing
Print Name and Title

Deputy State Fire Marshal Barbara McMullen
6403 W ROWAND DR
Spokane WA 99219
(509) 954-2746


Signature