



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Panorama City
Address 1751 Circle Lane SE,
City, State, Zip Lacey, WA

Provider Number 001161
Approval Status Approved
Facility Type Residential Care

On 10/08/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Erin Kimball
Signature

Erin Kimball, AH Admin.
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

R. Murcia
Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Panorama City	Provider Number	001161
Address	1751 Circle Lane SE,	Approval Status	Disapproved
City, State, Zip	Lacey, WA	Facility Type	Residential Care

On 08/18/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Testing and Maintenance

Sprinkler systems shall be tested and maintained in accordance with Section 901.

(IFC 903.5 2021)

Findings during the inspection were;

Sprinkler report from 9/30/24 states fire department hydrostatic test failed. Deficiency shall be corrected.

2 Extinguishing System Service

Automatic fire-extinguishing systems shall be serviced not less frequently than every six months and after activation of the system. Inspection shall be by qualified individuals, and a certificate of inspection shall be forwarded to the fire code official upon completion.

(IFC 904.13.5.2 2021)

Findings during the inspection were;

Facility failed to provide documentation showing kitchen suppression system is being inspected twice a year.

3 Inspection, Testing and Maintenance

The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.5 and NFPA 72. Records of inspection, testing and maintenance shall be maintained.

(IFC 907.8 2021)

Findings during the inspection were;

Facility failed to provide annual inspection report for fire alarm system. Fire alarm shall be inspected semi-annually.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Panorama City	Provider Number	001161
Address	1751 Circle Lane SE,	Approval Status	Disapproved
City, State, Zip	Lacey, WA	Facility Type	Residential Care

On 08/18/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after: 09/22/2025

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Erin Kimball
Signature

Erin Kimball, AL Admin
Print Name and Title

Deputy State Fire Marshal Raul Murcia
PO BOX 42642
Olympia WA 98504
(360) 819-0067

R. Murcia
Signature

This document was prepared by Residential Care Services for the Locator website.