



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Chandler's Square
Address 1300 O AVE ,
City, State, Zip Anacortes, WA
Provider Number 001190
Approval Status Approved
Facility Type Residential Care

On 11/13/2025 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

COMPLAINT # 200610

Here's a complaint of Fire Panel

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

Complaint ref # 200610

At 1415 on 11/13/2025, DSFM Brown conducted complaint inspection for Chandlers Square located at 1300 O Ave, Anacortes, WA 98221 to investigate complaint ref # 200610. I interviewed the Facility Maintenance Director.

On 11/02/2025, at approximately 0330, the facility lost power. The night staff assumed that the fire alarm system was not operational and started fire watch. The fire alarm was on battery power and still operational during the outage. Facility Maintenance Director will conduct training with staff.

No injuries were report.

No violations observed.

Next inspection scheduled on or after:


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

NICOLE OLIVER-BRITTKMAN, BOM
Print Name and Title

Deputy State Fire Marshal Brandon G. Brown
MP 235 SB Interstate 5
Bow WA 98232
(360) 791-7037


Signature